


INDUSTRY PUBLIC UTILITIES COMMISSION CITY OF INDUSTRY



REGULAR MEETING AGENDA
APRIL 11, 2024, 8:30 A.M.

President Cory C. Moss
Commissioner Michael Greubel
Commissioner Cathy Marcucci
Commissioner Mark D. Radecki
Commissioner Newell W. Ruggles



Location: City Council Chambers, 15651 Mayor Dave Way, City of Industry, California

Addressing the Commission:

- < **Agenda Items:** Members of the public may address the Commission on any matter listed on the Agenda. Anyone wishing to speak to the Commission is asked to complete a Speaker's Card which can be found at the back of the room and at the podium. The completed form should be submitted to the City Clerk prior to the Agenda item being called and prior to the individual being heard by the Commission.
- < **Public Comments (Non-Agenda Items):** Anyone wishing to address the Commission on an item not on the Agenda may do so during the "Public Comments" period. In order to conduct a timely meeting, there will be a one-minute time limit per person for the Public Comments portion of the Agenda. State law prohibits the Commission from taking action on a specific item unless it appears on the posted Agenda. Anyone wishing to speak to the Commission is asked to complete a Speaker's Card which can be found at the back of the room and at the podium. The completed card should be submitted to the City Clerk prior to the Agenda item being called and prior to the individual being heard by the Commission.

At the time of publication, no Commissioners intend to take part in the meeting remotely under the provisions of AB 2449. Should that change between the time of publication and the start of the meeting, a live webcasting of the meeting will be accessible via the link, meeting ID, and meeting passcode listed below. Whenever possible, an announcement will be made at the start of the meeting via the live webcast to confirm whether or not a Commissioner will join remotely. If they will not be joining remotely, then the live webcast will terminate after the announcement.

www.microsoft.com/microsoft-teams/join-a-meeting

Meeting ID: 232 775 135 178

Meeting Passcode: v5CBwn

Or call in (audio only)

+1 657-204-3264

Phone Conference ID: 414 242 29#

Americans with Disabilities Act:

- < In compliance with the ADA, if you need special assistance to participate in any City meeting (including assisted listening devices), please contact the City Clerk's Office (626) 333-2211. Notification of at least 48 hours prior to the meeting will assist staff in assuring that reasonable arrangements can be made to provide accessibility to the meeting.

Agendas and other writings:

- < *In compliance with SB 343, staff reports and other public records permissible for disclosure related to open session agenda items are available at City Hall, 15625 Mayor Dave Way, City of Industry, California, at the office of the City Clerk during regular business hours, Monday through Thursday 8:00 a.m. to 5:00 p.m., Friday 8:00 a.m. to 4:00 p.m. Any person with a question concerning any agenda item may call the City Clerk's Office at (626) 333-2211.*
-

1. Call to Order
2. Flag Salute
3. AB 2449 Vote on Emergency Circumstances (if necessary)
4. Roll Call
5. Presentations
6. **CONSENT CALENDAR**

All matters listed under the Consent Calendar are considered to be routine and will be enacted by one vote. There will be no separate discussion of these items unless members of the Industry Public Utilities Commission (IPUC) request specific items be removed from the Consent Calendar for separate action.

- 6.1 Consideration of the Register of Demands for March 28, 2024

RECOMMENDED ACTION: Ratify the Register of Demands for March 28, 2024.

- 6.2 Consideration of the Register of Demands for April 11, 2024

RECOMMENDED ACTION: Approve the Register of Demands and authorize the appropriate IPUC officials to pay the bills.

- 6.3 Report from the General Manager for the La Puente Valley County Water District regarding the Industry Public Utilities Water Operations

RECOMMENDED ACTION: Receive and file the report.

- 6.4 Consideration of an Amended and Restated Energy Efficiency Program, effective January 1, 2024

RECOMMENDED ACTION: Approve the Amended and Restated Energy Efficiency Program.

- 6.5 Consideration of an Energy Efficiency Program Reimbursement to Kelly Spicers, for the property located at 288 South Brea Canyon Road, in the amount of \$29,059.89

RECOMMENDED ACTION:
reimbursement.

Approve

the

7. **ACTION ITEMS-NONE**

8. **PUBLIC HEARINGS-NONE**

9. **CLOSED SESSION-NONE**

10. **PUBLIC UTILITIES DIRECTOR COMMENTS**

11. **AB 1234 REPORTS**

12. **COMMISSIONER COMMUNICATIONS**

13. **PUBLIC COMMENTS**

14. Adjournment. The next regular Industry Public Utilities Commission Meeting is Thursday, May 9, 2024, at 8:30 a.m.

INDUSTRY PUBLIC UTILITIES COMMISSION

ITEM NO. 6.1

INDUSTRY PUBLIC UTILITIES COMMISSION


AUTHORIZATION FOR PAYMENT OF BILLS

Board Meeting March 28, 2024


| <u>FUND</u> | <u>DESCRIPTION</u> | <u>DISBURSEMENTS</u> |
|-----------------|----------------------------------|----------------------|
| 122 | IPU-ELECTRIC CAPITAL IMPROVEMENT | 26,110.00 |
| 161 | IPUC ELECTRIC FUND | 837,070.62 |
| TOTAL ALL FUNDS | | 863,180.62 |

| <u>BANK</u> | <u>DESCRIPTION</u> | <u>DISBURSEMENTS</u> |
|-----------------|---------------------------------|----------------------|
| EEPWFBK | IPUC EEP WELLS FARGO CHK | 49,408.20 |
| IPUCELEC.WF | IPUC ELECTRIC WELLS FARGO CKING | 813,772.42 |
| TOTAL ALL BANKS | | 863,180.62 |

APPROVED PER PUBLIC UTILITIES DIRECTOR



DATE



**Industry Public Utilities Commission
Wells Fargo - Electric
March 28, 2024**

| Check | Date | Payee Name | | Check Amount |
|--|-------------------|-------------------------------------|--|---------------------|
| IPUCELEC.WF.CHK - IPUC Electric Wells Fargo CHK | | | | |
| 11431 | 03/20/2024 | FRONTIER | | \$163.97 |
| | Invoice | Date | Description | Amount |
| | 2024-00001619 | 03/04/2024 | 3/4-4/3/24 SVC-21620 VALLEY BLVD | \$65.04 |
| | 2024-00001620 | 03/04/2024 | 3/4-4/3/24 SVC-21858 GARCIA LN WALNUT | \$98.93 |
| 11432 | 03/28/2024 | ASTRUM UTILITY SERVICES, LLC | | \$17,000.00 |
| | Invoice | Date | Description | Amount |
| | 022401 | 03/04/2024 | CONSULTING SVC FOR IPUC-FEB 2024 | \$17,000.00 |
| 11433 | 03/28/2024 | CNC ENGINEERING | | \$45,436.25 |
| | Invoice | Date | Description | Amount |
| | 509834 | 03/14/2024 | AUTOMATIC METER READING | \$3,245.00 |
| | 509836 | 03/14/2024 | DISTRIBUTION LINE EXTENSION @ 999 HATCHER AVE | \$22,865.00 |
| | 509833 | 03/14/2024 | ELECTRICAL CAPITAL IMPROVEMENTS-IBC | \$10,921.25 |
| | 509835 | 03/14/2024 | CITY ELECTRICAL FACILITIES | \$8,405.00 |
| 11434 | 03/28/2024 | PACIFIC UTILITY INSTALLATION | | \$14,260.00 |
| | Invoice | Date | Description | Amount |
| | 29288 | 02/09/2024 | UTILITY OPERATIONS & SVC'S-FEB 2024 | \$14,260.00 |
| 11435 | 03/28/2024 | REXEL ENERGY SOLUTIONS | | \$736,672.20 |
| | Invoice | Date | Description | Amount |
| | S136889483.004 | 02/28/2024 | FURNISH 242 STREETLIGHT POLES & LUMINAIRE LIGH | \$97,411.20 |
| | S136889483.003 | 02/28/2024 | FURNISH 242 STREETLIGHT POLES & LUMINAIRE LIGH | \$639,261.00 |
| 11436 | 03/28/2024 | THE TECHNOLOGY DEPOT | | \$174.00 |

**Industry Public Utilities Commission
Wells Fargo - Electric
March 28, 2024**

| Check | Date | Payee Name | Check Amount |
|-------|------|------------|--------------|
|-------|------|------------|--------------|

IPUCELEC.WF.CHK - IPUC Electric Wells Fargo CHK

| Invoice | Date | Description | Amount |
|---------|------------|-------------------------------------|----------|
| 25736 | 02/22/2024 | CLOUD CONNECT-WADDINGHAM SUBSTATION | \$174.00 |

| | | | | |
|--------------|------------|--|--|----------------|
| 11437 | 03/28/2024 | | UNDERGROUND SERVICE ALERT OF \$ | \$66.00 |
|--------------|------------|--|--|----------------|

| Invoice | Date | Description | Amount |
|-----------|------------|---|---------|
| 220240163 | 03/01/2024 | DIG ALERTS MONTHLY DATABASE MAINT FEE-FEB 202 | \$66.00 |

| Checks | Status | Count | Transaction Amount |
|--------|--------|-------|---------------------|
| | | Total | 7 |
| | | | \$813,772.42 |

Industry Public Utilities Commission
Wells Fargo - Electric Energy
March 28, 2024

| Check | Date | Payee Name | Check Amount |
|-------|------|------------|--------------|
|-------|------|------------|--------------|

IPUCEEP.WF.CHK - IPUC EEP WELLS FARGO CK

| | | | |
|--------|-----------------|--------------------------------------|-------------|
| 500008 | 03/28/2024 | GASKELL TEP LLC | \$49,408.20 |
| | Invoice | Description | Amount |
| | GW2B01-2024 IPU | 03/20/2024 RENEWABLE ENERGY-JAN 2024 | \$49,408.20 |

| Checks | Status | Count | Transaction Amount |
|--------|--------|-------|--------------------|
| | Total | 1 | \$49,408.20 |

INDUSTRY PUBLIC UTILITIES COMMISSION

ITEM NO. 6.2

INDUSTRY PUBLIC UTILITIES COMMISSION

AUTHORIZATION FOR PAYMENT OF BILLS

Board Meeting April 11, 2024

| <u>FUND</u> | <u>DESCRIPTION</u> | <u>DISBURSEMENTS</u> |
|-----------------|----------------------------------|----------------------|
| 122 | IPU-ELECTRIC CAPITAL IMPROVEMENT | 21,667.50 |
| 123 | IPU-WATER CAPITAL IMPROVEMENT | 20,917.50 |
| 161 | IPUC ELECTRIC FUND | 276,314.08 |
| 560 | IPUC WATER FUND | 67,165.95 |
| TOTAL ALL FUNDS | | 386,065.03 |

| <u>BANK</u> | <u>DESCRIPTION</u> | <u>DISBURSEMENTS</u> |
|-----------------|---------------------------------|----------------------|
| IPUCELEC.WF | IPUC ELECTRIC WELLS FARGO CKING | 297,981.58 |
| IPUC.CHK | IPUC WATER BOFA CKING | 88,083.45 |
| TOTAL ALL BANKS | | 386,065.03 |

APPROVED PER PUBLIC UTILITIES DIRECTOR



DATE

4-11-24

**Industry Public Utilities Commission
Wells Fargo - Electric
April 11, 2024**

| Check | Date | | Payee Name | Check Amount |
|--|---------------|------------|---|--------------------|
| IPUCELEC.WF.CHK - IPUC Electric Wells Fargo CHK | | | | |
| 11427 | 03/13/2024 | | ENCO UTILITY SERVICES | \$19,268.00 |
| | Invoice | Date | Description | Amount |
| | INV64231 | 03/01/2024 | CUSTOMER ACCT SVC-FEB 2024 | \$19,268.00 |
| 11428 | 03/13/2024 | | FRONTIER | \$2,063.38 |
| | Invoice | Date | Description | Amount |
| | 2024-00001547 | 02/22/2024 | 2/22-3/21/24 SVC-21733 BAKER PKWY BLDG 21 | \$60.99 |
| | 2024-00001548 | 02/22/2024 | 2/22-3/21/24 SVC-21858 VALLEY BLVD | \$65.04 |
| | 2024-00001549 | 02/25/2024 | 2/25-3/24/24 SVC-21760 GARCIA LN | \$98.93 |
| | 2024-00001550 | 02/25/2024 | 2/25-3/24/24 SVC-21535 BAKER PKWY BLDG 20 | \$60.99 |
| | 2024-00001601 | 03/01/2024 | 3/1-3/31/24 SVC-VARIOUS SITES | \$1,449.37 |
| | 2024-00001602 | 02/29/2024 | 2/28-3/27/24 SVC-179 S GRAND AVE | \$42.11 |
| | 2024-00001603 | 02/29/2024 | 2/28-3/27/24 SVC-21700 BAKER PKWY BLDG 23 | \$60.99 |
| | 2024-00001604 | 02/29/2024 | 2/28-3/27/24 SVC-21912 GARCIA LANE WALNUT | \$98.93 |
| | 2024-00001605 | 03/01/2024 | 3/1-3/31/24 SVC-21650 VALLEY BLVD | \$60.99 |
| | 2024-00001606 | 03/01/2024 | 3/1-3/31/24 SVC-21700 VALLEY BLVD | \$65.04 |
| 11429 | 03/13/2024 | | NEXTERA ENERGY MARKETING, LLC | \$76,072.80 |
| | Invoice | Date | Description | Amount |
| | 852519 | 03/04/2024 | WHOLESALE USE-FEB 2024 | \$76,072.80 |
| 11430 | 03/13/2024 | | SOUTHERN CALIFORNIA EDISON | \$16,202.37 |
| | Invoice | Date | Description | Amount |
| | 2024-00001545 | 03/01/2024 | 2/1-2/29/24 SVC-VARIOUS SITES | \$246.09 |
| | 2024-00001546 | 03/01/2024 | 2/1-2/29/24 SVC-208 S WADDINGHAM | \$2,975.37 |
| | 2024-00001598 | 03/01/2024 | 2/1-2/29/24 SVC-208 S WADDINGHAM | \$12,980.91 |

Industry Public Utilities Commission
Wells Fargo - Electric
April 11, 2024

| Check | Date | Payee Name | | Check Amount |
|--|-----------------|--------------------------------------|--|--------------------|
| IPUCELEC.WF.CHK - IPUC Electric Wells Fargo CHK | | | | |
| 11438 | 03/27/2024 | CALPINE ENERGY SOLUTIONS, LLC | | \$90,094.99 |
| | Invoice | Date | Description | Amount |
| | 240820019502028 | 03/22/2024 | WHOLESALE USE-FEB 2024 | \$90,094.99 |
| 11439 | 03/27/2024 | FRONTIER | | \$1,441.09 |
| | Invoice | Date | Description | Amount |
| | 2024-00001642 | 03/09/2024 | 3/9-4/8/24 SVC-208 WADDINGHAM WAY | \$904.17 |
| | 2024-00001643 | 03/10/2024 | 2/28-3/27/24 SVC-21700 BAKER PKWY BLDG 23 | \$60.99 |
| | 2024-00001644 | 03/10/2024 | 3/10-4/9/24 SVC-21640 VALLEY BLVD | \$60.99 |
| | 2024-00001645 | 03/10/2024 | 3/10-4/9/24 SVC-21808 GARCIA LN WALNUT | \$98.93 |
| | 2024-00001646 | 03/07/2024 | 3/7-4/6/24 SVC-408 BREA CYN RD WALNUT | \$49.70 |
| | 2024-00001647 | 03/10/2024 | 3/10-4/9/24 SVC-747 S ANAHEIM PUENTE RD | \$266.31 |
| 11440 | 04/03/2024 | FRONTIER | | \$479.07 |
| | Invoice | Date | Description | Amount |
| | 2024-00001660 | 03/19/2024 | 3/19-4/18/24 SVC-21415 BAKER PKWY | \$60.99 |
| | 2024-00001661 | 03/19/2024 | 3/19-4/18/24 SVC-21660 VALLEY BLVD | \$71.14 |
| | 2024-00001662 | 03/19/2024 | 3/19-4/18/24 SVC-21438 BAKER PKWY BLDG #25 | \$60.99 |
| | 2024-00001687 | 03/22/2024 | 3/22-4/21/24 SVC-21733 BAKER PKWY BLDG 21 | \$60.99 |
| | 2024-00001688 | 03/22/2024 | 3/22-4/21/24 SVC-21858 VALLEY BLVD | \$65.04 |
| | 2024-00001689 | 03/25/2024 | 3/25-4/24/24 SVC-21535 BAKER PKWY BLDG 20 | \$60.99 |
| | 2024-00001690 | 03/25/2024 | 3/25-4/24/24 SVC-21760 GARCIA LN | \$98.93 |
| 11441 | 04/03/2024 | SOUTHERN CALIFORNIA EDISON | | \$11,154.88 |
| | Invoice | Date | Description | Amount |

**Industry Public Utilities Commission
Wells Fargo - Electric
April 11, 2024**

| Check | Date | | Payee Name | Check Amount |
|--|------------|------------|---|--------------------|
| IPUCELEC.WF.CHK - IPUC Electric Wells Fargo CHK | | | | |
| | 7501660851 | 03/18/2024 | 2/1-2/29/24 SVC-745 ANAHEIM-PUENTE RD | \$1,027.46 |
| | 7501660858 | 03/18/2024 | 2/1-2/29/24 SVC-208 S WADDINGHAM WAY | \$8,266.71 |
| | 7501660857 | 03/18/2024 | 2/1-2/29/24 SVC-133 N AZUSA AVE | \$1,860.71 |
| 11442 | 04/11/2024 | | ASTRUM UTILITY SERVICES, LLC | \$17,000.00 |
| | Invoice | Date | Description | Amount |
| | 032401 | 04/01/2024 | CONSULTING SVC FOR IPUC-MAR 2024 | \$17,000.00 |
| 11443 | 04/11/2024 | | CNC ENGINEERING | \$54,370.00 |
| | Invoice | Date | Description | Amount |
| | 509931 | 03/28/2024 | CAPITAL IMPROVEMENTS-IBC | \$20,630.00 |
| | 509933 | 03/28/2024 | CITY ELECTRICAL FACILITIES | \$12,072.50 |
| | 509932 | 03/28/2024 | AUTOMATIC METER READING | \$2,760.00 |
| | 509934 | 03/28/2024 | DISTRIBUTION LINE EXTENSION @ 999 HATCHER AVE | \$18,907.50 |
| 11444 | 04/11/2024 | | NV5, INC. | \$9,835.00 |
| | Invoice | Date | Description | Amount |
| | 379334 | 03/20/2024 | ON CALL ELEC ENG SVC-FEB 2024 | \$2,040.00 |
| | 379339 | 03/20/2024 | ON CALL ELEC ENG SVC-FEB 2024 | \$6,010.00 |
| | 379327 | 03/20/2024 | ON CALL ELEC ENG SVC-FEB 2024 | \$1,785.00 |

| Checks | Status | Count | Transaction Amount |
|--------------|--------|-----------|---------------------|
| Total | | 11 | \$297,981.58 |

**Industry Public Utilities Commission
Bank of America - Water
April 11, 2024**

| Check | Date | | Payee Name | Check Amount |
|--|-----------------|------------|---|--------------------|
| IPUC.CHK - IPUC Water BofA Checking | | | | |
| 40730 | 03/14/2024 | | INDUSTRY PUBLIC UTILITIES COMMIS | \$8,565.20 |
| | Invoice | Date | Description | Amount |
| | R10312023-A | 10/01/2023 | IH GOLF COARSE RECYCLED WATER-OCT 2023 | \$8,565.20 |
| 40731 | 03/14/2024 | | ROWLAND WATER DISTRICT | \$46,573.42 |
| | Invoice | Date | Description | Amount |
| | I-10312023-B | 10/31/2023 | CONTRACT SVC-OCT 2023 | \$1,799.07 |
| | I-10312023-A | 10/31/2023 | CONTRACT SVC-OCT 2023 | \$21,456.65 |
| | I-10312023-D | 10/31/2023 | PROFESSIONAL SVC-OCT 2023 | \$23,317.70 |
| 40732 | 03/20/2024 | | L A COUNTY TAX COLLECTOR | \$9,192.42 |
| | Invoice | Date | Description | Amount |
| | 8920 851 459 23 | 12/10/2023 | PROP TAX FY 23/24-WATER DIST SYSTEM | \$682.15 |
| | 8920 851 456 23 | 12/10/2023 | PROP TAX FY 23/24-WATER DIST SYSTEM | \$3,943.30 |
| | 8920 851 458 23 | 12/10/2023 | PROP TAX FY 23/24-WATER DIST SYSTEM | \$86.79 |
| | 8920 851 457 23 | 12/10/2023 | PROP TAX FY 23/24-WATER DIST SYSTEM | \$4,480.18 |
| 40733 | 03/20/2024 | | VALLEY VISTA SERVICES, INC | \$252.51 |
| | Invoice | Date | Description | Amount |
| | 664145 | 02/13/2024 | IPU WATER-14063 PROCTOR AVE | \$252.51 |
| 40734 | 04/11/2024 | | CNC ENGINEERING | \$22,387.50 |
| | Invoice | Date | Description | Amount |
| | 509937 | 03/28/2024 | PUENTE BASIN WATERMASTER ISSUES | \$1,470.00 |
| | 509935 | 03/28/2024 | LOMITAS GENERATOR | \$5,327.50 |
| | 509936 | 03/28/2024 | PROCTOR YARD BLDG | \$15,590.00 |

**Industry Public Utilities Commission
Bank of America - Water
April 11, 2024**

| Check | Date | Payee Name | | Check Amount |
|--|------------|---|---|-----------------|
| IPUC.CHK - IPUC Water BofA Checking | | | | |
| 40735 | 04/11/2024 | INDUSTRY PUBLIC UTILITIES COMMIS | | \$250.00 |
| | Invoice | Date | Description | Amount |
| | MAR-24 | 03/19/2024 | REPLENISH PAYROLL ACCT FOR MARCH 2024 | \$250.00 |
| 40736 | 04/11/2024 | INDUSTRY PUBLIC UTILITIES COMMIS | | \$862.40 |
| | Invoice | Date | Description | Amount |
| | FEB-24 | 03/11/2024 | TRANSFER FROM IPUC WATER TO IPUC RECYCLED W | \$862.40 |

| Checks | Status | Count | Transaction Amount |
|--------|--------|-------|--------------------|
| | Total | 7 | \$88,083.45 |

INDUSTRY PUBLIC UTILITIES COMMISSION

ITEM NO. 6.3
Verbal Presentation

INDUSTRY PUBLIC UTILITIES COMMISSION

ITEM NO. 6.4



INDUSTRY PUBLIC UTILITIES COMMISSION

MEMORANDUM

TO: Honorable President Moss and Commissioners

FROM: Joshua Nelson, City Manager

STAFF: Mathew Hudson, Engineering Manager
Dev Birla, Senior Energy Adviser, CNC Engineering

DATE: April 11, 2024

SUBJECT: Consideration of an Amended and Restated Energy Efficiency Incentive Program Effective January 1, 2024

Background:

The Commission approved the Energy Efficiency (“EE”) Incentive Program for IPU customers on March 28, 2019, to promote energy efficiency and reduce the peak demand, and the program has been in effect since April 15, 2019. On April 8, 2021, the amended and restated EE Incentive Program was approved, based on the feedback from IPU customers. Some of the changes included: increasing the cap amount of the EE Incentive Program from \$25,000.00 to \$50,000.00 for Large General Service customers, adding this program as a routine line item in the annual fiscal year budget, clarifying the language that LED Lighting Retrofit Incentive applies to both indoor and outdoor lighting, and adjusting the EE Program Incentive per kWh to match the actual cost of power supply at that time.

Staff have observed during last three years that all customers’ projects fall under Large General Service Lighting Incentive Program. Based on this observation, Staff has determined that Paragraph 1.2 of the program needs further fine tuning to include the kW peak reduction incentive of \$150/kW, in addition to the energy consumption reduction incentive of \$0.059 per kWh. This proposed change in the EE Incentive Program is attached hereto as Exhibit A.

Discussion:

Staff believes that there is a lack of interest from the customers to participate in the EE Incentive Program partially due to lack of sufficient compensation and reimbursement. Prior to January 1, 2024, the last rebate request was received on May 12, 2022 from HD Maintenance Facilities, located at 21651 and 21535 Baker Parkway.

Staff reviewed the EE Incentive Program and noticed that under paragraph 1.2 of the Large General Service Lighting Incentive Program, the compensation for the reduction in

peak kW demand was not included. The fine-tuning of this paragraph is necessary to compensate the customers for the reduction in both energy consumption and the kW peak demand to stimulate the customers participation in this program. Staff recommends making this change effective January 1, 2024, to benefit all customers under the Large General Service Lighting Incentive Program.

Fiscal Impact:

No additional fiscal impact to already required each fiscal year budget for Public Benefit Charge under Account No. 161-300-6415.

Recommendation:

It is hereby recommended that the IPUC approve the Amended and Restated EE Incentive Program, effective January 1, 2024.

Exhibit:

A. Amended and Restated EE Incentive Program dated April 11, 2024

JN/MH/DB:jf

EXHIBIT A

Amended and Restated EE Incentive Program dated April 11, 2024

[Attached]

IPU Energy Efficiency Programs

April 11, 2024

The Industry Public Utilities (“IPU”) Energy Efficiency (“EE”) Programs outlines the parameters for customers to receive incentives and rebates for the installation of eligible Energy Efficiency Measures (“EEMs”), equipment or systems, and for IPU to receive payments for eligible projects that benefit IPU customers through energy efficiency, conservation, or reduced peak-demand. EE Program payments to customers are based on expected annual energy savings, while funding for IPU projects is based on actual project costs. The EE Program is funded by the IPU’s Public Purpose Program.

EE Programs

Currently IPU provides electric service to 114 customers. Sixty-nine with monthly maximum demand greater than 20 kilowatts (“kW”) are classified as Large General Service; thirty non-residential customers with monthly maximum demand less than 20 kW are classified as General Service; and fifteen residential customers are classified as Domestic Service. The IPU’s EE Program is designed to encourage energy efficient lighting systems and the exploration and implementation of energy efficient technologies. These technologies may address either equipment or operational change, and if IPU can quantify a demand reduction and/or energy savings, there is a basis for providing an incentive or a rebate to assist the customer achieve its energy efficiency goals. The EE Program provides incentives in four program categories: Large General Service Program; General Service Program; Domestic Service Program; and IPU EEM. The EE Incentive Program will be part of annual fiscal year budget effective fiscal year 2021-2022 and 2.85% of forecasted gross revenue of IPU.

1. Large General Service Program. Large General Service customers are eligible to receive energy efficiency rebates based upon the annual kilowatt hour (“kWh”) savings, and or kilowatt (“kW”) peak-demand reduction, as calculated or accepted by IPU. Customers must schedule an onsite energy audit prior to installation and onsite post verification of installation; submit an EE Program application, including energy savings calculations and paid invoices, within 90 days of the project completion. A customer is only eligible to receive up to \$50,000.00 over the two-year budget cycle; unless otherwise approved by the IPUC.

1.1 Energy Audits: On-site energy audits and recommendations are designed to potentially improve energy operating efficiency and reduce load requirements. IPU Large General Service customers are eligible for one ASHRAE Level I, II, or III energy audits at no cost once every two years. The number of energy audits completed each fiscal year shall be limited based on available funding. Energy audits will be scheduled.

on a first-come, first-serve basis according to the date the EE Program application is received. The energy audit procedures are attached as Appendix B.

12 Lighting Incentives: EE Program payment for the installation of energy efficiency lighting upgrades that reduce annual energy usage. This lighting upgrade can be interior inside the building as well as exterior building security lights and include parking lot lights as long as the power source is coming from IPU. A pre and post inspection is required. The EE Program payment is based on a rate of \$0.059 /kWh for one year of energy savings and \$150/kW for each on-peak kW that has been reduced and shall not exceed 50 percent of the lighting material cost.

13 Customized Incentives: EE Program payment for the installation of energy efficient equipment/technology that conserves energy and permanently reduces coincident summer/winter peak demand and exceeds state-mandated codes, federal-mandated codes, industry accepted performance standards or other baseline energy performance standards. EE Program payment is based on a rate of \$0.059/kWh for one year of energy savings and \$150/kW for each on-peak kW that has been reduced and shall not exceed 50 percent of the total cost associated with the equipment/materials.

14 Construction Incentives: One-time EE Program payment for construction projects that include equipment components that exceed state-mandated codes, federal-mandated codes, industry-accepted performance standards, or other baseline energy performance standards by more than 10 percent. The EE Program payment is based on the lesser of 25 percent of the cost difference between standard and upgraded equipment and/or materials.

- 2. General Service Program.** General Service customers must schedule an energy survey to receive a one-time program allowance, for the installation of specified energy measures, up to \$1,000.00 every two years. A description of the energy survey process is included in Appendix C and a list of the direct installed measures are included in Appendix E.

21 Energy Surveys: Energy survey of General Service customer's facilities and financial feasibility of recommended energy efficiency measures.

22 Direct Install Program: This program offers a list of energy efficiency measures including: light-emitting diode ("LED") lighting upgrades; lighting controls; refrigeration upgrades; Heating/Ventilation/Air-Conditioning ("HVAC") tune-ups; and pumps and motor replacement.

- 3. Domestic Service Program.** Residential customers are eligible to receive a rebate of approved Energy Star® appliances up to \$250.00 per residence; and program allowance for the installation of specified energy measures, up to \$500.00 every two

years. A description of the direct installed and rebate programs is described in Appendix D and a list of the direct installed measures are included in Appendix E.

31 Domestic Rebate Program: The qualified list of IPUC approved Energy Star® appliances are included in Appendix D.

32 Direct Install Program: The Domestic Direct Install Program includes an energy survey of the residence, energy survey report and direct installed measures. This program offers a list of energy efficiency measures including: energy efficiency lighting; HVAC tune-up and filter change out; and programmable/smart thermostat.

4. IPU Energy Efficiency Measures. Payment for eligible projects must be authorized by the IPUC and shall not exceed \$10,000.00 per year.

41 IPU Energy Efficiency Measures: Payment for IPU energy efficiency measures promote a benefit to IPU customers in terms of energy efficiency, conservation, or reduced peak-demand.

V. EE Program Terms and Conditions:

1. Participants are limited to IPU and its electric customers with all associated utility accounts in good standing.
2. The Public Utilities Director or designee reserves the right to temporarily suspend the EE Program, or any component thereof, at any time. However, cancellation of or any permanent modifications to the EE Program must be approved by the IPUC.
3. Payments issued under EE Program Categories are limited to the availability of funds.
4. Independent of the EE Program payment, eligible energy efficiency projects must be cost effective from the customer's perspective based upon the value of total estimated energy savings over the life of the installed measures. The installed equipment must have a useful life of at least five years.
5. Demand reduction and direct energy savings attributable to energy efficiency must be evaluated by IPU's engineering consulting firm using accepted industry calculations or energy model. Savings calculations must include product specifications, hours of operations, the derivation of baseline conditions and all other assumptions used to support estimates.
6. Energy savings can be incentivized based on calculations using existing conditions of equipment or using efficiency values based on either accepted State (California Code of Regulations Title 24) or federal standards, whichever is higher.

7. When there is uncertainty of energy savings or demand reduction, IPU may require measurement and verification (M&V) up to two years after installation of the project. If IPU determines that M&V is necessary, IPU customer service will request that the applicant prepare and submit an M&V plan for review and approval by the Public Utilities Director or designee. For projects where M&V is required, 100 percent of the approved rebate/incentive will be paid after the project installation is confirmed, upon the final M&V report.
8. To verify eligibility and reserve funding, initial EE Program applications must be submitted to the IPU Electrical Utility Operations Manager or online on IPU Website, and pre-approved by the IPU Engineer or designee before equipment is installed. The EE Program application must be accompanied by the estimates of demand reduction and annual energy savings outlined in Section V.5. above. Upon review of the application, IPU Electrical Utility Operations Manager will arrange to conduct a pre-inspection by IPU engineering consultant to verify the conditions of the preexisting equipment and field verify the proposed project. IPU Engineer or designee will provide written notice to the applicant of pre-approval status and determination of potential eligible amount based on the pre-inspection report. The funding reservation, pre-inspection, and M&V requirements, if applicable, shall be included in such notice.
9. EE Program payment requests must be submitted by the applicant, in writing, within 120 days of issuance of the pre-approval notice to prevent cancellation of the funding reservation. Written requests must be accompanied by sufficient information to document project costs and must include, at a minimum, a copy of the dated sales receipt. The sales receipt is subject to verification and must note all necessary information to properly identify the qualifying product/equipment/materials, including, but not limited to: make/model, vendor, date, and price per qualifying unit. IPU might also conduct a post-inspection to verify the installation of the energy efficiency measure.
10. Payments will only be issued to IPU customers for projects that demonstrate an overall reduction in usage or demand as required under the appropriate EE Program Category, as determined and approved by the IPU Engineer or designee.
11. EE Program applications are subject to pre- and post-installation inspections. Customer agrees to fully cooperate with any authorized agents of IPU for the purpose of such inspections. Customers who are not in compliance with terms and conditions of the EE Program, or to have provided false or inaccurate information on the EE Program application will be billed up to the full amount of the rebate, as may be appropriate.
12. All equipment installed must be new (not used, refurbished, or available for resale); used at the service address listed on the EE Program application; replace existing, operational, less energy-efficiency equipment; and utilize the same fuel source as existing equipment (electric for electric, not gas for electric).

13. With the exception of IPU Projects, rebates/incentives are based on product cost only. Labor, equipment rentals, taxes and non-material costs are excluded.
14. Individual Large Service General customers may not receive EE Program incentives in excess of \$50,000.00 during any given two years life of the program unless recommended by IPU staff and specifically approved by the IPUC. Upon approval of the incentives and rebates, the check will be issued by IPU and should be expected to arrive to the customer no later than six weeks after.
15. Rebate checks will only be issued and mailed to the IPU customer listed on the application for service or as indicated in an official notification subsequently submitted to IPU in writing following the initial application for service.
16. If the Customer is not satisfied with the EE Program incentive provided, the Customer may appeal to the IPUC. The appeal must be submitted in writing to the IPUC, together with the reasons for the dispute within ten (10) days following mailing of the Public Utilities Director or designee's determination. In the absence of a timely filed appeal, the Public Utilities Director or designee's determination will be final. Upon receipt of a timely appeal, the matter will be reviewed by the IPUC within 45 days of receipt. A written final decision of the IPUC shall be delivered to the Customer by personal delivery or certified mail within fifteen days following the appeal hearing.
17. IPU does not endorse or recommend specific products or dealers and disclaims any warranty, whether expressed or implied, regarding the equipment installed, or for any material or labor associated with its installation, maintenance, repair, safety, satisfactory performance, or any energy savings associated with its use

Appendix A

IPU

American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) Energy Audit Procedures

1. Level I Audit

A Level I audit, which may also be called a site assessment audit or preliminary audit, is used to identify no-cost and low-cost energy saving opportunities, and a general view of potential capital improvements. Activities include an assessment of energy bills and a brief site inspection of the facility.

The steps to be taken and scope of services provided under a Level I Audit are as follows:

- 1.1. IPU Representative will either schedule a meeting with facility staff or request an in-person meeting. During the initial contact, IPU Representative will collect:
 - 1.1.1. Business name, address, phone number, facility square footage and usage type
 - 1.1.2. Customer contact name, address, phone number and e-mail address
 - 1.1.3. Building owner name, address, phone number and e-mail address
 - 1.1.4. One year of the most recent electric utility bill information

- 1.2. If scheduled in advance, prior to the meeting, IPU Representative will prepare for the meeting by:
 - 1.2.1. Reviewing and analyzing the energy bills to identify any unusual usage patterns
 - 1.2.2. Benchmarking the buildings energy consumption and comparing it to similar buildings based on the Energy Use Intensity (EUI)

- 1.3. IPU Representative will conduct an initial high-level interview with the building owner or the building owner's representative and the facility manager (when applicable). IPU Representative will:
 - 1.3.1. Discuss goals and objectives of the audit as well as the deliverables
 - 1.3.2. Discuss the audit schedule, escorts and points of contact for the IPU Representative. Also, discuss any trade secrets, potential for industrial espionage, or facility areas that are "off limits"
 - 1.3.3. Discuss any safety and security protocols observed at the site and equipment access procedures
 - 1.3.4. Determine customer's processes, systems, lighting, HVAC, controls and other equipment, and how they are used
 - 1.3.5. Determine and document operating schedules, shift work, controls and operational characteristics of the different areas of the facility
 - 1.3.6. Discuss and document customer-specific financial considerations and issues

- 1.3.7. Discuss and document any critical equipment or functions that cannot contribute to energy efficiency solutions, or that the customer is unwilling to modify
- 1.3.8. If available, review facility site map to develop strategy for site walkthrough
- 1.3.9. Collect facility information:
 - 1.3.9.1. Year Built
 - 1.3.9.2. Utility Meter Information
 - 1.3.9.3. Hours of Operation (Weekdays & Weekends)
 - 1.3.9.4. Number of Stories
 - 1.3.9.5. Single Tenant/Multi-Tenant?
 - 1.3.9.6. Annual Percent Occupancy
 - 1.3.9.7. HVAC system type(s)
- 1.4. IPU Representative will conduct a walkthrough and document all possible low-cost and no-cost recommendations, whether or not they have immediate potential for inclusion in the project. This may include pictures, nameplate data and details regarding:
 - 1.4.1. Building envelope
 - 1.4.2. Lighting
 - 1.4.3. Heating and cooling
 - 1.4.4. Refrigeration
 - 1.4.5. Miscellaneous Equipment
- 1.5. IPU Representative will conduct data analysis of the facility including:
 - 1.5.1. Benchmarking the buildings energy consumption and comparing it to similar buildings based on the Energy Use Intensity (EUI)
 - 1.5.2. The energy analysis will include a review of the existing equipment to identify low-cost and no-cost recommendations in addition to capital improvements
 - 1.5.3. The cost analysis will include a review of current energy costs, measure implementation costs, potential energy cost savings per year, possible rebate and incentive amounts and simple payback period.
- 1.6. IPU Representative will create a report including the following:
 - 1.6.1. Cover Page: The Report shall begin with a cover page identifying Customer, title of the audit, address of the facility, and date completed.
 - 1.6.2. Executive Summary: The executive summary is intended to provide the important findings of the audit at a glance. This will include a statement on the scope and methodology of the audit.
 - 1.6.3. Facility Description: A brief description of the facility, square footage, hours of operation, use, location
 - 1.6.4. Benchmarking: Comparing the building's energy use to similar buildings based on the Energy Use Intensity (EUI)
 - 1.6.5. Energy Efficiency Opportunities: This subsection lists the measures found and provides a brief explanation of low-cost and no-cost energy savings opportunities

- 1.6.5.1. Measure Identification Number #
- 1.6.5.2. Measure Description
- 1.6.5.3. Measure Quantity
- 1.6.5.4. Description of Energy Saving Opportunities
- 1.6.5.5. Rough Estimate on Project Implementation/Retrofit Cost (\$)
- 1.6.5.6. Estimated Utility Rebates/Incentives (if applicable) (\$)
- 1.6.5.7. Estimated Simple Payback
- 1.6.5.8. Potential measures for future consideration

1.7. After the report is complete, but before presenting to the customer, IPU Representative's engineering department will review all measures, paybacks, estimated costs and evaluations. The report will be modified until it meets requirements. Once approved by IPU, IPU Representative will present the findings to the customer.

2. Level II Audit

Level II audits, also called energy surveys or engineering analysis audits, identify no-cost and low-cost opportunities, as well as potential capital-intensive energy savings opportunities. Level II audits include an in-depth analysis of energy costs, energy usage and building characteristics, and a more refined survey of how energy is used in the facility.

A Level II audit will be implemented for those measures that the customer selects from the Level I audit report. It is also possible for a customer to request a Level II audit without a Level I audit performed if that customer verifies that the resulting products for selected equipment are viable within the next year. The customer may proceed with measure implementation following the Level I Audit without having a Level II Audit.

The Level II audit will entail a detailed analysis on measures selected by the customer, or the measures considered by the IPU Representative to be cost-effective. Each measure will be accompanied with detailed energy saving calculations, cost estimates and financial analysis. In addition to Level I activities, the Level II audit report will include the following:

2.1. During the initial contact, IPU Representative will collect:

- 2.1.1. Two years of the most recent electric utility bill information
- 2.1.2. The building as-built plans, and mechanical and electrical schedules
- 2.1.3. A detailed HVAC equipment list from the building's current HVAC contractor (if applicable) to cross reference with the as-built plans

2.2. IPU Representative will conduct a detailed interview with the building owner or the building owner's representative, the facility manager and facility Engineer (when applicable)

- 2.2.1. Determine customer's preference of return-on-investment (ROI) or payback period
 - 2.2.2. Determine and document operating schedules, occupancy (especially multi-tenant situations), process operation, shift work, controls and operational characteristics of the different areas of the facility. The purpose is to gain a better understanding of the customer's needs, wants and expectations regarding energy efficiency, and to compile a complete inventory of all energy consuming devices at the site
- 2.3. IPU Representative will conduct a thorough walkthrough of the facility and document all existing equipment, whether or not they have immediate potential for inclusion in the project. This may include pictures of, and data on:
- 2.3.1. Building envelope
 - 2.3.1.1. Construction details including orientation, construction material type, insulation levels, glazing type and area on each side
 - 2.3.2. Lighting
 - 2.3.2.1. Type, hours of use and control type and count
 - 2.3.3. Heating, Ventilation and Air Conditioning (HVAC) System
 - 2.3.3.1. Nameplate information on each piece of system equipment, hours of operation and zones served
 - 2.3.4. Process/heavy equipment
 - 2.3.4.1. Nameplate information on each piece of equipment, hours of operation, count
 - 2.3.5. Refrigeration
 - 2.3.5.1. Nameplate information on each piece of equipment, count
 - 2.3.6. Miscellaneous Equipment
 - 2.3.6.1. Nameplate information on each piece of equipment, hours of operation, count
- 2.4. Detailed equipment energy analysis, as selected by the customer or determined by the IPU Representative for possible recommendations, including:
- 2.4.1. HVAC System: An analysis on the HVAC system will include: system type; capacity; confirmed or estimated age of equipment, efficiency; Expected Useful Life (EUL); and number of units. A special note will be written if the equipment exceeds its useful life. Reference how the system was designed and how it is currently operating, and highlight any major differences discovered through the audit process
 - 2.4.2. Building Controls: The analysis will include: manufacturer; year installed; equipment being controlled; and protocols used by the system
 - 2.4.3. Lighting: The analysis will include: type, wattage; quantity; how the lighting is being controlled (sensors, daylight harvesting, control system, etc.); and the typical facility hours of operation for each lighting system
 - 2.4.4. Refrigeration: The analysis will include: compressor type; wattage; quantity; and evaporator fan motor type and controls
 - 2.4.5. Compressed Air: The analysis will include: system components; layout; equipment nameplate data; usage type; and hours of operation

- 2.4.6. Miscellaneous Equipment: The analysis will include: type; wattage; quantity; and hours of operation
- 2.5. IPU Representative will create a detailed energy audit report including:
 - 2.5.1. Cover Page: The report will contain a cover page identifying the customer; title of the audit; address of the facility; and date completed.
 - 2.5.2. Executive Summary: The executive summary is intended to provide the important findings of the audit at a glance. This will include: a detailed facility description; current conditions; and summary of savings from the energy efficiency recommendations.
 - 2.5.3. Building Envelope: A description of the building's orientation; construction material type; insulation levels; glazing type; and area on each side.
 - 2.5.4. Utility Billing: This will include an analysis on the electric consumption for the previous twelve months and the average rate charge.
 - 2.5.5. Energy Balancing: The goal of the energy balance is to calibrate the facility's energy consumption and the existing equipment with information collected during the audit such as hours of operation and equipment nameplate data.
 - 2.5.6. Detailed End-use Breakdown: This will include a percent and chart breakdown for each equipment type obtained from the energy balancing. The end-use breakdown is used to better understand the building and be able to compare it with similar facilities.
 - 2.5.7. Energy Efficiency Recommendations: This portion of the report will include a description of the existing equipment and the recommended upgrades or replacement equipment. Only cost-effective measures, as determined by the energy analysis, will be presented to the customer as recommendations.
 - 2.5.7.1. Measure Identification Number #
 - 2.5.7.2. Measure Type (energy efficiency, demand response, distributed generation)
 - 2.5.7.3. Measure Description
 - 2.5.7.4. Measure Location(s)
 - 2.5.7.5. Measure Quantity
 - 2.5.7.6. Description of Energy Efficiency Opportunities
 - 2.5.7.7. Detailed energy and cost savings
 - 2.5.7.8. Potential measures for future consideration
 - 2.5.8. Detailed energy and cost analysis on energy efficiency recommendations will include:
 - 2.5.8.1. Energy demand reduction (kW)
 - 2.5.8.2. Annual electric consumption savings (kWh)
 - 2.5.8.3. Bill impact analysis with net annual cost savings (\$)
 - 2.5.8.4. Total Measure/Project Implementation/Retrofit Cost (\$)
 - 2.5.8.5. Assumptions and references (RSMMeans, actual quotes, etc.)
 - 2.5.8.6. Detailed payback analysis to include simple payback, internal rate of return (IRR), and other customer-specific financial analyses.
 - 2.5.9. Utility Programs: Detailed list of rebate and incentive programs offered by the customer's utility provider.
 - 2.5.10. Equipment Inventory: Detailed list of all equipment found on the facility

- 2.5.10.1. Electrical
- 2.5.10.2. Mechanical

2.6. After the report is complete, but before presenting to the customer, IPU Representative's engineering department will review all measures, paybacks, estimated costs and evaluations. The report will be modified until it meets requirements. Once approved by IPU, IPU Representative will present the findings to the customer.

3. Level III Audit

A Level III audit, also called a detailed analysis of capital-intensive modification audit or investment grade audit, provides detailed recommendations and financial analysis for major capital investments related to energy conservation. In addition to Level I and Level II activities, Level III audits include monitoring/metering equipment, Building Energy Modeling (BEM) and custom engineering analysis.

A Level III audit may be implemented for those measures that the customer selects from the Level II audit report or for targeted capital investments.

The steps taken and scope of services provided under a Level III audit are:

- 3.1. Perform an audit to collect building and equipment information, as outlined in Level I and Level II audits with the addition of:
 - 3.1.1. Determine the HVAC zoning per unit
 - 3.1.2. Collect square footage of each zone
 - 3.1.3. Collect equipment and lighting information per zone
 - 3.1.4. Determine specific processes performed on-site
- 3.2. Meter/record detailed information on targeted equipment performance
 - 3.2.1. Determine which equipment requires monitoring or trending data (energy measurements prior to project starting) include, but are not limited to:
 - 3.2.1.1. Pneumatic to Electric Air Dryers
 - 3.2.1.2. Blowers
 - 3.2.1.3. Chiller Compressor Retrofit
 - 3.2.1.4. Chiller Cross Tie (Cross Connect)
 - 3.2.1.5. Chiller Replacement (if multiple chillers at site)
 - 3.2.1.6. Commercial Laundry with Heat Recovery
 - 3.2.1.7. EMS or DDC Installation
 - 3.2.1.8. Engine Jacket Water Heating
 - 3.2.1.9. Central Plant Optimization (Hartman Loop)
 - 3.2.1.10. Pump Replacement (pump check analysis to establish efficiency of the pump)
 - 3.2.1.11. Pump VFD and Pump Station VFD
 - 3.2.1.12. Fan VFD

- 3.2.2. Review mechanical or electrical equipment plans and determine the data type that needs to be collected and monitored. Strategize on meter location
 - 3.2.3. Install data logger, current transducers or applicable sensor type
 - 3.2.4. Record required data for prescribed period
- 3.3. Analyze whole building performance with a Building Energy Modeling (BEM) software
- 3.3.1. Construct an energy model of the current building and baseline conditions, specifics include:
 - 3.3.1.1. Building shell(s): building type, envelope, orientation, glazing type, climate zone, HVAC zoning, square footage
 - 3.3.1.2. HVAC system type and location: Chiller, package unit, split unit, condenser coil, boilers, cooling towers, air handlers, make-up air units, ventilation fans, etc.
 - 3.3.1.3. Lighting: Lighting Power Density (LPD) per zone
 - 3.3.1.4. Equipment: Watts per square foot for each zone
 - 3.3.1.5. Miscellaneous Equipment: Watts per square foot for each zone
 - 3.3.1.6. Controls: Include any existing controls such as VFDs, EMS, daylight harvesting, occupancy sensors, etc.
 - 3.3.1.7. Occupancy: Include the number of people per facility/zone and the percent occupancy depending on building type (per day/week/month)
 - 3.3.1.8. Schedules: Include the specific operation hours for equipment, elevators, HVAC units, interior and exterior lighting
 - 3.3.2. Calibrate the energy model to 10% (or less) of the billing data to accurately simulate energy performance
 - 3.3.2.1. Normalize billing data to increase monthly energy consumption accuracy
 - 3.3.2.2. Analyze and adjust equipment usage until the energy model is well calibrated to meet the required building performance
 - 3.3.3. Conduct parametric runs to simulate each energy efficiency measure
 - 3.3.3.1. Analyzes each energy efficiency measure and provides detailed energy and demand savings
 - 3.3.3.2. Calculates the interactive effects each measure will have on other systems and the positive or negative effects on the building's energy consumption
- 3.4. Perform high precision cost and savings calculations
- 3.4.1. Perform customized engineering calculations for equipment that requires metering
 - 3.4.2. Detailed financial analysis, incorporating estimated project cost, rebates, incentives, projected savings from detailed engineering analysis and finance assumptions
- 3.5. IPU Representative will create a detailed energy audit report including:

- 3.5.1. Cover Page: The report will contain a cover page identifying the customer, title of the audit, address of the facility and date completed.
- 3.5.2. Executive Summary: The executive summary is intended to provide the important findings of the audit at a glance. This will include a detailed facility description, current conditions and summary of savings from the energy efficiency recommendations.
- 3.5.3. Building Envelope: A description of the building's orientation, construction material type, insulation levels, glazing type and area on each side
- 3.5.4. Utility Billing: This will include an analysis on the electric consumption for the previous twelve months and the average rate charge.
- 3.5.5. Energy Balancing: The goal of the energy balance is to calibrate the facility's energy consumption and the existing equipment with information collected during the audit such as hours of operation and equipment nameplate data.
- 3.5.6. Detailed End-use Breakdown: This will include a percent and chart breakdown for each equipment type obtained from the energy balancing. The end-use breakdown is used to better understand the building and be able to compare it with similar facilities.
- 3.5.7. Energy Efficiency Recommendations: This portion of the report will include a description of the existing equipment and the recommended upgrades or replacement equipment. Only cost-effective measures, as determined by the energy analysis, will be presented to the customer as recommendations:
 - 3.5.7.1. Measure Identification Number #
 - 3.5.7.2. Measure Type (energy efficiency, demand response, distributed generation)
 - 3.5.7.3. Measure Description
 - 3.5.7.4. Measure Location(s)
 - 3.5.7.5. Measure Quantity
 - 3.5.7.6. Description of Energy Efficiency Opportunities
 - 3.5.7.7. Detailed energy and cost analysis
 - 3.5.7.8. Potential measures for future consideration
- 3.5.8. Detailed energy and cost analysis on energy efficiency recommendations will include:
 - 3.5.8.1. Energy demand reduction (kW)
 - 3.5.8.2. Annual electric consumption savings (kWh)
 - 3.5.8.3. Bill impact analysis with net annual cost savings (\$)
 - 3.5.8.4. Total Measure/Project Implementation/Retrofit Cost (\$)
 - 3.5.8.5. Assumptions and references (RS Means, actual quotes, etc.)
 - 3.5.8.6. Detailed payback analysis to include simple payback, internal rate of return (IRR), and other customer-specific financial analyses
- 3.5.9. Utility Programs: Detailed list of rebate and incentive programs offered by the customer's utility provider
- 3.5.10. Equipment Inventory: Detailed list of all equipment found on the facility
 - 3.5.10.1. Electrical
 - 3.5.10.2. Mechanical

After the report is complete, but before presenting to the customer, IPU Representative's engineering department will review all measures, paybacks, estimated costs and evaluations. The report will be modified until it meets requirements. Once approved by IPU, IPU Representative will present the findings to the customer.

Appendix B
IPU Energy Efficiency Program
General Service Energy Survey Process and Direct Install Program

1. Energy Survey Process and Direct Install Program

- 1.1 The IPU Representative will meet with the General Service customer and if necessary, receive a "Property Owner's Agreement" signed by the property owner or property manager.
- 1.2 The IPU Representative will conduct a walk-through and enter in the database all the applicable energy measures for lighting, heating, cooling, and equipment.
- 1.3 Consistent with IPU EE Policy, IPU Representative will recommend the appropriate energy efficiency measures to be installed.
- 1.4 With the Customer and IPU's approval, IPU Representative will install the energy efficiency measures recommended.
- 1.5 The General Service customer or property manager will sign the work order listing the measures installed.

Appendix C
IPU
Domestic Direct Install and Rebate Program

1. Energy Survey Process and Direct Install Program

- 1.1 The IPU Representative will meet with the residential customer and if necessary, receive a “Property Owner’s Agreement” signed by the property owner or property manager for each rental unit that will be participating.
- 1.2 The IPU Representative will conduct a walk-through and enter in the database all the applicable energy measures for lighting, heating, cooling, and equipment.
- 1.3 Consistent with IPU EE Policy, IPU Representative will recommend the appropriate energy efficiency measures to be installed.
- 1.4 With the Customer and IPU’s approval, IPU Representative will install the energy efficiency measures recommended.
- 1.5 The homeowner or property manager will sign the work order listing the measures installed.

2. Domestic Rebate Program

| Energy Star® Equipment | Rebate Amount (\$) | Energy Star Estimated Annual Savings* (kWh) |
|-------------------------------|---------------------------|--|
| LED Lights (5-10 Watts) | \$5.00 | Varies |
| LED Lights (11-20 Watts) | \$8.00 | Varies |
| LED Lights (>20 Watts) | \$10.00 | Varies |
| Refrigerator | \$100.00 | 185.0 |
| Freezer | \$50.00 | 47.0 |
| Dishwasher | \$50.00 | 25.0 |
| Programmable/Smart Thermostat | \$125.00 | Varies |
| Ceiling Fan | \$50.00 | 48.6 |
| Clothes Washer | \$200.00 | 49.5 |
| Window Air Conditioner Unit | \$50.00 | 918.0 |

*Estimated Annual Savings are from Energy Star or the U.S. Department of Energy.

Appendix D
 IPU Energy Efficiency Program
 General Services and Domestic Direct Install Measures

Listed below is the description of the installed measures included in the Direct Install Program and the allowance provided to General Service and Residential Customers

| Measure Code | Installed Measure | Measure Price |
|------------------------------------|--|---------------|
| <i>INTERIOR LIGHTING</i> | | |
| Linear Fluorescent Retrofit | | |
| LGT362 | 4ft 4L 32W T8 High Perf w/EB | \$ 80.00 |
| LGT367 | 4ft 4L 32W T8 High Perf w/2EB | \$ 93.00 |
| LGT373 | 4ft 3L 32W T8 High Perf w/2EB | \$ 85.00 |
| LGT373a | 4ft 3L 32W T8 High Perf w/Elec | \$ 72.00 |
| LGT383 | 4ft 2L w/EB (Retro) | \$ 58.00 |
| LGT381 | 4ft 2L T8 U6 w/EB | \$ 71.00 |
| LGT393 | 4ft 1L 32W T8 High Perf w/EB | \$ 56.00 |
| LGT401 | 8ft 4L T8 High Perf w/2EB | \$142.00 |
| LGT404 | 8ft 4L T8 High Perf w/EB | \$111.00 |
| LGT405 | 8ft 2L T8 w/EB | \$100.00 |
| LGT406 | 8ft 2L 28-32W w/EB & retro kit | \$112.00 |
| LGT403 | 8ft 2L T8HO w/EB (Retrofit) | \$146.00 |
| LGT407 | 8ft 1L T8 w/EB | \$ 80.00 |
| LGT408 | 6ft 4L 28-32W w/EB & retro kit | \$110.00 |
| LGT409 | 6ft 2L 28-32W w/EB & retro kit | \$ 93.00 |
| LGT410 | 3ft 2L 25W 2nd gen T8 w/EB | \$ 65.50 |
| LGT412 | 3ft 1L 25W 2nd gen T8 w/EB | \$ 60.00 |
| LGT415 | 3ft 4L 25W 2nd gen T8 w/EB (6-ft conv kit) | \$ 95.00 |
| LGT416 | 2ft 4L F17 2nd gen T8 w/EB | \$ 68.00 |
| LGT420 | 2ft 2L 32T8 U6 w/EB | \$ 1.00 |
| LGT422 | 2ft 2L F17 2nd gen T8 w/EB | \$ 0.00 |
| LGT425 | 2ft 1L F17 2nd gen T8 w/EB | \$ 57.00 |
| LGT426 | 4ft tube guard | \$ 10.00 |

| | | |
|---|---|----------|
| LGT427 | 8ft tube guard | \$ 10.00 |
| PARTS01_042017 | Clear Acrylic Lens Cover (wrap fixture) | \$ 59.00 |
| PARTS01 | Clear Acrylic Lens Cover | \$ 18.00 |
| Linear Fluorescent New Fixture | | |
| LGT377 | 4ft 2L w/EB (New Fixt) | \$111.00 |
| LGT403a | 8ft 2L T8HO w/EB (New Fixt) | \$137.00 |
| T8 Lamps | | |
| LGT 347 | 8ft T8 Bulbs Only | \$ 9.00 |
| LGT 347 | 4ft T8 Bulbs Only | \$ 7.00 |
| INTERIOR LIGHTING T8 DELAMPING | | |
| 4ft Retrofit / Delamping | | |
| LGT461 | 4ft 3L T8 Retro/Delamp | \$102.00 |
| LGT462 | 4ft 2L T8 Retro/Delamp | \$ 74.00 |
| 4ft New Fixture / Delamping | | |
| | 4ft 4L T8 New Fix/Delamp | \$166.00 |
| LGT463 | 4ft 3L T8 New Fix/Delamp | \$163.00 |
| LGT464 | 4ft 2L T8 New Fix/Delamp | \$154.00 |
| 4ft F25T8 retrofit / Delamping with Anti-Striation Ballast | | |
| LGT610 | 4ft 3 Lamp F25T8 Retrofit | \$125.00 |
| LGT611 | 4ft 2 Lamp F25T8 Retrofit | \$ 96.00 |
| LGT612 | 4ft 1 Lamp F25T8 Retrofit | \$ 89.00 |
| HID Replacement to Linear Florescent Fixture | | |
| LGT473 | 4ft 4 Lamp T8 High Bay Fixture | \$264.00 |
| LGT474 | 4ft 2 Lamp T5HO High Bay Fixture | \$270.00 |
| LGT475 | 4ft 6 Lamp T8 High Bay Fixture | \$288.00 |
| LGT476 | 4ft 4 Lamp T5HO High Bay Fixture | \$300.00 |
| LGT477 | 4ft 8 Lamp T8 High Bay Fixture | \$327.00 |
| LGT478 | 4ft 6 Lamp T5HO High Bay Fixture | \$335.00 |

| | | |
|--------------|--|----------|
| LGT479 | 4ft 10 Lamp T8 High Bay Fixture | \$442.00 |
| LGT480 | 4ft 8 Lamp T5HO High Bay Fixture | \$428.00 |
| | 8ft T12 HO Exterior Retrofit to 8ft T8 HO | |
| LGT481 | 8ft 1 Lamp T8HO Exterior Retrofit | \$ 92.00 |
| LGT482 | 8ft 2 Lamp T8HO Exterior Retrofit | \$103.00 |
| LGT483 | 8ft 3 Lamp T8HO Exterior Retrofit | \$137.00 |
| LGT484 | 8ft 4 Lamp T8HO Exterior Retrofit | \$162.00 |
| LGT485 | 8ft 6 Lamp T8HO Exterior Retrofit | \$207.00 |
| | CFL | |
| LGT428 | CFL 5-13W** | \$ 21.00 |
| | 5 W Screw-n CFL** | \$ 21.00 |
| | 7 W Screw-in CFL** | \$ 21.00 |
| | 9 W Screw-in CFL** | \$ 21.00 |
| LGT428c | 9 W Globe CFL** | \$ 21.00 |
| | 13W/60W Spiral - Indoor CFL** | \$ 21.00 |
| | CFL 14-26W | |
| | 11 W Screw-in CFL** | \$ 21.00 |
| LGT429i | 14 W A-Type Screw-in** | \$ 22.00 |
| LGT429a | 14W Screw-in CFL** | \$ 17.00 |
| LGT429l | 18W Screw-in CFL** | \$ 22.00 |
| LGT429k | 23W Screw-in CFL** | \$ 18.00 |
| LGT430 | >= 27W** | \$ 25.00 |
| LGT430a_0715 | 1 27W/100W Spiral Indoor CFL** | \$ 22.00 |
| LGT432 | CFL 11W R20** | \$ 21.00 |
| | 9 W R20 Flood Type** | \$ 21.00 |
| LGT432a | 11 W R20 Flood Type R20 2700K** | \$ 22.00 |
| | 11 W R20 Flood Type R20 4000K** | \$ 22.00 |
| LGT433 | CFL 15W R30** | \$ 21.00 |
| LGT433e | 9W CFL Candle/Base** | \$ 19.00 |
| LGT433 | CFL Indoor Flood, 14 W R20** | \$ 22.00 |
| LGT433a | CFL Indoor Flood, 15 W R30 2700K** | \$ 22.00 |
| LGT434e | 23W CFL PAR38 2700K** | \$ 25.00 |
| LGT434f | 14W CFL PAR20 2700K** | \$ 19.00 |
| LGT434g | 19 W CFL R40 2700K** | \$ 25.00 |
| | 19 W Screw-in Par 38 CFL** | \$ 23.00 |
| | 20 W Screw-in Par 38 CFL** | \$ 23.00 |

| | | |
|--------|--|----------|
| | CFL Indoor Flood, 20 W R40 2700K** | \$ 23.00 |
| | CFL Indoor Flood, 20 W R30 3200K** | \$ 23.00 |
| LGT435 | CFL Indoor Flood, 25 W R30 2700K** | \$ 21.00 |
| LGT436 | 32W CRL Wall Pack Fixture** | \$129.00 |
| LGT437 | CFL 65W Floodlight Fixture** | \$132.00 |
| LGT438 | CFL 65W Yardlight Fixture** | \$129.00 |
| | PAR16 / MR16 Incandescent to CFL 9-11 W PAR16 | |
| LGT558 | 9W PAR16** | \$ 32.00 |
| LGT559 | 11W PAR16** | \$ 32.00 |
| | PAR20 Incandescent to CFL 9- 14W PAR20 | |
| LGT560 | 9W PAR20** | \$ 30.00 |
| LGT561 | 11W PAR20** | \$ 30.00 |
| LGT562 | 14W PAR20** | \$ 30.00 |
| | PAR30 Incandescent to CFL 15- 19W PAR30 | |
| LGT564 | 19W PAR30** | \$ 30.00 |
| | PAR38 CFL 19-23W PAR38 | |
| LGT565 | 19W PAR38** | \$ 31.00 |
| LGT566 | 20W PAR38** | \$ 31.00 |
| LGT567 | 23W PAR38** | \$ 31.00 |
| | PAR16 / MR16 Incandescent to CMH PAR16 | |
| LGT568 | 20W PAR16** | \$109.80 |
| | PAR20 Incandescent to CMH PAR20 | |
| LGT569 | 20W PAR20** | \$ 72.00 |
| LGT570 | 39W PAR20** | \$ 85.00 |
| | PAR30 Incandescent to CMH PAR30 | |
| LGT571 | 20W PAR30** | \$ 60.00 |
| LGT572 | 35W PAR30** | \$ 72.00 |
| LGT573 | 70W PAR30** | \$ 85.00 |
| | HID Fixture Replacement to CFL | |
| LGT579 | 80W CFL Spiral 120V Retrofit** | \$162.00 |

| | | |
|--|--------------------------------------|----------|
| LGT584 | 100W CFL Spiral 120V/277V Retrofit** | \$174.00 |
| LGT587 | 150W CFL Spiral 120V/277V Retrofit** | \$195.00 |
| LGT588 | 200W CFL Spiral 120V/277V Retrofit** | \$209.00 |
| HID Wall pack Replacement to CFL Wall pack | | |
| LGT590 | 42W CFL Wall pack Fixture** | \$148.00 |
| Chandelier Incandescent replacement to CFL Chandelier | | |
| LGT596 | 2W CFL Tear Drop Candelabra** | \$ 26.00 |
| LGT597 | 14W CFL Tear Drop Candelabra** | \$ 26.00 |
| LGT598 | 5W CFL Flame Tip Bulb** | \$ 26.00 |
| LGT617 | Cold Cathode CFL (1-6W)** | \$ 26.00 |
| LGT617a | Cold Cathode CFL (7-15W)** | \$ 31.00 |
| LED LIGHTING | | |
| 4ft LED Retrofit | | |
| LGT486 | 4ft 4L Linear LED Retrofit | \$149.00 |
| LGT486_2c_0317 | 4ft 3L (6pc) LED Retrofit Bi-Level | \$142.00 |
| LGT486a | 4ft 4L LED Retrofit Plug-n-Play | \$108.00 |
| LGT487 | 4ft 3L Linear LED Retrofit | \$116.00 |
| LGT487_1b_0717APU | 4FT 2L LED lamp only Plug-n-Play | \$ 55.00 |
| LGT487_1c_0717APU | 4FT 4L LED lamp only Plug-n-Play | \$ 81.00 |
| LGT487_1d_0717APU | 4FT 3L LED lamp only Plug-n-Play | \$ 68.00 |
| LGT487a | 4ft 3L LED Retrofit Plug-n-Play | \$ 95.00 |
| LGT488 | 4ft 2L Linear LED Retrofit | \$ 96.00 |
| LGT487b | 4ft 4L LED (New Fixt) | \$192.00 |
| LGT488a | 4ft 2L LED Retrofit Plug-n-Play | \$ 80.00 |
| LGT489a | 4ft 1L LED Retrofit Plug-n-Play | \$ 67.00 |
| LGT489a_0216 | 4ft 1L Linear LED Retrofit | \$ 81.00 |
| LGT489_2b | 4ft 1L (2pc) LED Retrofit | \$ 73.00 |
| LGT486_2a_1 | 2ft 2L U6 (3pc) LED Retrofit | \$ 90.00 |
| LGT486_2a | 4ft 2L (4pc) LED Retrofit | \$ 98.00 |
| LGT486_2c | 4ft 3L (6pc) LED Retrofit | \$120.00 |
| LGT-LED-09 | 4ft 4L (8pc) LED Retrofit | \$153.00 |

| 4ft T8 Tubes with Daylight Harvesting (Ballast with Sensor) | | |
|---|---|----------|
| LGT451-B (LGT451 in database) | 4ft 1L LED With Daylight Harvesting Ballast and sensor | \$191.00 |
| LGT451-B (LGT451 in database) | 4ft 2L LED With Daylight Harvesting Ballast and sensor | \$209.00 |
| LGT452 | 4ft 3L LED With Daylight Harvesting Ballast and sensor | \$230.00 |
| LGT453 | 4ft 4L LED With Daylight Harvesting Ballast and sensor | \$248.00 |
| 4ft T8 Strips with Daylight Harvesting (Ballast with Sensor) | | |
| LGT451-B (LGT451 in database) | 4ft (2 PCS) LED With Daylight Harvesting Ballast and sensor | \$190.00 |
| LGT451-B (LGT451 in database) | 4ft (4 PCS) LED With Daylight Harvesting Ballast and sensor | \$206.00 |
| LGT452 | 4ft (6 PCS) LED With Daylight Harvesting Ballast and sensor | \$226.00 |
| LGT453 | 4ft (8 PCS) LED With Daylight Harvesting Ballast and sensor | \$242.00 |
| 4ft LED Retrofit / Delamping | | |
| LGT490 | 4ft 3L LED Retrofit 57W | \$137.00 |
| LGT491 | 4ft 2L LED Retrofit 38W | \$ 99.00 |
| LGT492 | 4ft 1L LED Retrofit 19W | \$ 84.00 |
| 4ft LED New Fixture / Delamping | | |
| LGT493 | 4ft 3L LED New Fixture | \$205.00 |
| LGT494 | 4ft 2L LED New Fixture | \$180.00 |
| LGT495 | 4ft 1L LED Fixture 19W | \$145.00 |
| Chandelier Incandescent replacement to LED Chandelier | | |
| LGT497 | 3W LED Dimmable Candelabra | \$ 34.00 |
| Incandescent Replacement to LED | | |
| LGT500 | 9W A-type LED | \$ 34.00 |
| LGT503 | 12W A-type LED | \$ 34.00 |
| LGT504 | 7W Globe-Type LED | \$ 37.07 |
| LGT506 | 9W Globe-Type LED | \$ 40.00 |
| LGT509 | 12W Globe-Type LED | \$ 40.00 |
| PAR16 / MR16 incandescent to LED 2-6 W PAR16 / MR16 | | |
| LGT539_2b | LED 5W PAR/MR16 | \$ 42.00 |
| LGT539_2c | LED 5W GU10 PAR/MR16 | \$ 44.00 |

| | | |
|--|------------------------------|----------|
| LGT541 | 4W PAR16 | \$ 42.00 |
| LGT542 | 6W PAR16 | \$ 42.00 |
| LGT542a | 10W PAR16 | \$ 42.00 |
| PAR20 Incandescent to LED 3-9W PAR20 | | |
| LGT543 | 3W PAR20 | \$ 39.00 |
| LGT544 | 4W PAR20 | \$ 39.00 |
| LGT545 | 6W PAR20 | \$ 39.00 |
| LGT546 | 8W PAR20 | \$ 39.00 |
| PAR30 Incandescent to LED 7- 19W PAR30 | | |
| LGT547 | 7W PAR30 | \$ 45.00 |
| LGT547_2b | LED 16W PAR30 | \$ 45.00 |
| LGT547a_0715 | 8W PAR30 | \$ 45.00 |
| LGT548 | 10W PAR30 | \$ 45.00 |
| LGT549 | 11W PAR30 | \$ 45.00 |
| LGT550 | 13W PAR30 | \$ 45.00 |
| LGT551 | 14W PAR30 | \$ 45.00 |
| LGT552 | 15W PAR30 | \$ 45.00 |
| LGT553 | 19W PAR30 | \$ 45.00 |
| PAR38 Incandescent to LED 16- 23W PAR38 | | |
| LGT554a | 13W PAR38 | \$ 50.00 |
| LGT554 | 16W PAR38 | \$ 50.00 |
| LGT555 | 20W PAR38 | \$ 50.00 |
| LGT556 | 23W PAR38 | \$ 50.00 |
| LED Wall Packs | | |
| LGT510_2a_0818 | 100W LED Bulb | \$285.00 |
| LGT510 | 30W LED Wall Pack 5000K | \$292.50 |
| LGT511 | 60W LED Wall Pack 5000K | \$326.00 |
| LGT512 | 90W LED Wall Pack 5000K | \$356.00 |
| LGT512b_0317 | 80W LED Wall Pack High Power | \$423.00 |
| LGT512_b_0921 | 150W LED Wallpack High Power | \$543.00 |
| LGT512_C | 200W LED Wallpack High Power | \$711.00 |
| LGT512_D | 300W LED Wallpack High Power | \$837.00 |
| HID to LED | | |

| | | |
|------------------------------|---|----------|
| LGT513 | 100W LED Highbay 5000K (Warehouse) | \$403.00 |
| LGT514 | 240W LED Highbay 5000K (Warehouse) | \$526.00 |
| LGT514a_0317(AvJet) | 320W LED High Bay Fixture 5000K | \$630.00 |
| Flood Lights | | |
| LGT515_1 | 30W LED Flood Light | \$209.00 |
| LGT515_2 | 50W LED Flood Light | \$239.00 |
| Area/Street Lighting | | |
| LGT515_4 | 50W Area/Street Light 5000K | \$366.00 |
| LGT515_5 | 80W Area/Street Light 5000K | \$457.00 |
| LGT515_6 | 100W Area/Street Light 5000K | \$571.00 |
| LGT515_7 | 150W Area/Street Light 5000K | \$610.00 |
| LGT515_8 | 200W Area/Street Light 5000K | \$725.00 |
| LGT515_9 | 300W Area/Street Light 5000K | \$852.00 |
| Canopy Station | | |
| LGT515_10 | 40W LED Canopy Light 5000K | \$282.00 |
| LGT515_11 | 60W LED Canopy Light 5000K | \$340.00 |
| LGT515_12 | 90W LED Canopy Light 5000K | \$506.00 |
| LGT515_13 | 120W LED Canopy Light 5000K | \$542.00 |
| Gas Station | | |
| LGT515_14 | 40W LED Gas Station Canopy Light 5000K | \$349.00 |
| LGT515_15 | 60W LED Gas Station Canopy Light 5000K | \$459.00 |
| LGT515_16 | 90W LED Gas Station Canopy Light 5000K | \$515.00 |
| Downlights (Recessed) | | |
| LGT515_17 | 13W LED Downlight 4 Inch 5000K | \$119.00 |
| LGT515_18 | 22W LED Downlight 6 Inch 5000K | \$126.00 |

| | | |
|----------------------------|---|------------|
| LGT515_19 | 35W LED Downlight 8 Inch 5000K | \$176.00 |
| LED PANELS | | |
| | 2FT X 4 FT LED Flat Panel Retrofit | \$232.00 |
| | 2FT X 2FT LED Flat Panel Retrofit | \$232.00 |
| Solar Tubes | | |
| LGT627 | VELUX 10 in. Sun Tunnel Tubular Skylight with Rigid Tunnel and Low Profile Plastic and Metal Flashing | \$731.00 |
| LGT627 | ODL 10 in. Tubular Skylight with Seamless Composite Flashing | \$731.00 |
| LED EXIT/OPEN SIGNS | | |
| LGT439 | LED Exit Sign-Red Replacement Battery Back-up | \$118.00 |
| LGT440 | LED Exit Sign-Green Replacement Battery Back-up | \$118.00 |
| LGT500d | LED Open signs replaces Neon | \$151.00 |
| LGT500 | Green or Red Photo luminescent Exit Sign (Single sided) | \$158.00 |
| LGT501 | Green or Red Photo luminescent Exit Sign (Double sided) | \$256.00 |
| WINDOW FILM | | |
| HVACS202 | Medium Reflectivity Window Film | \$ 9.00 |
| HVACS202b_2 | Low Reflectivity Window Film | \$ 9.00 |
| HVACS202c_2 | High Reflectivity Window Film | \$ 9.00 |
| HVAC | | |
| HVACS203 | HVAC Tune-Up Basic Diagnostic < = 5 Ton Unit | \$210.00 |
| HVACS205 | HVAC Tune-Up Basic Diagnostic > = 5 Ton Unit | \$210.00 |
| HVACS206 | HVAC Tune-Up Basic Diagnostic > = 10 Ton Unit | \$230.00 |
| HVACS222 | HVAC Tune-Up Comprehensive Diagnostic < = 10 Ton Unit | \$530.00 |
| HVACS208 | Duct Sealing, Non-Residential CZ 15 (per Ton) | \$348.50 |
| HVACS208 | Duct Test and Seal >= 5 Ton Unit (ducting) | \$430.00 |
| HVACS209 | Ceiling Fan with Thermostatic Control 30" to 36" (tied to the HVAC System) | \$2,160.00 |

| | | |
|----------------------|--|------------|
| HVACS210 | Ceiling Fan with Thermostatic Control 42" to 44" (tied to the HVAC System) | \$2,300.00 |
| HVACS211 | Ceiling Fan with Thermostatic Control 52" to 56" (tied to the HVAC System) | \$2,645.00 |
| HVACS217 | Refrigerant, Non-Residential CZ 15 (per Ton) | \$161.50 |
| HVACS220 | Dirty Condenser Coil Cleaning | \$85.00 |
| T-STATS | | |
| HVACS207 | 7 Day Programmable Thermostat | \$150.00 |
| HVACS207f | 5 Day Programmable Thermostat | \$150.00 |
| HVACS208 | All in One Thermostat | \$150.00 |
| HVACS209 | Reprogramming/Education Existing Programmable Thermostats | \$ 86.00 |
| HVACS210 | Thermostat Lock Box | \$ 82.00 |
| | Smart Thermostat RTA | \$344.00 |
| | Smart Thermostat Nest | \$422.00 |
| | Smart Thermostat EcoBee3 | \$397.00 |
| | Smart Thermostat Honeywell | \$373.00 |
| | Common Wire attachment | \$156.00 |
| | Thermostat Training and Education | \$ 37.00 |
| | Outreach Customers for Thermostat | \$ 67.00 |
| | Hourly HVAC Service Tech Rate | \$ 68.00 |
| REFRIGERATION | | |
| APPLS008 | Refrigeration Curtains Med. Per Linear ft. | \$195.00 |
| APPLS008a | Freezer Curtains Med. Per Linear ft. | \$212.00 |
| Refrigeration | | |
| APPLS009_1 | Walk-In Cooler - Tune Up | \$196.00 |
| APPLS009_2 | Walk-In Freezer - Tune Up | \$196.00 |
| APPLS009_3 | Under Counter & Self Contained - Tune Up | \$196.00 |

| | | |
|---|---|----------|
| APPLS009_4 | Split Systems w/Multiple Coils - Tune Up | \$196.00 |
| APPLS010 | Refrigerator Main Cooler Door Gaskets Med. Temp. per Linear ft. | \$ 20.00 |
| APPLS011 | Freezer Main Cooler Door Gaskets Low Temp. per Linear ft. | \$ 20.00 |
| APPLS012 | Door Closer | \$199.00 |
| APPLS013 | Heavy duty UV Refrigeration Pipe-Insulation per Linear ft. | \$ 13.00 |
| APPLS21 Greenwize | Anti-Sweat Heat (ASH) Controls (or Humidistat Controls) Freezer | \$626.88 |
| APPLS21_1 Sentry | Anti-Sweat Heat (ASH) Controls (or Humidistat Controls) Freezer | \$466.88 |
| APPLS22 Greenwize | Anti-Sweat Heat (ASH) Controls (or Humidistat Controls) Cooler | \$584.38 |
| APPLS22_2 Sentry | Anti-Sweat Heat (ASH) Controls (or Humidistat Controls) Cooler | \$499.38 |
| APPLS23 | Replace Standard Fan Motors with Electronically Commutated Motors (ECM) | \$241.00 |
| APPLS23 | 16W Electronically Commutated Motor | \$205.00 |
| APPLS23-a | 1/15HP-1/20HP Electronically Commutated Motor | \$233.00 |
| APPLS24 | Install Fan Controllers | \$286.40 |
| APPLS25 | Suction Line Insulation (per linear foot) | \$ 20.00 |
| APPLS26 | Refrigerant charge for refrigerators/freezers (per pound) | \$ 86.00 |
| Refrigeration LED Retrofit | | |
| APPLS018 | 4ft 1L LED (Low Temp) | \$ 86.67 |
| APPLS018a | 5ft 1L LED (Low Temp) | \$116.24 |
| APPLS019 | 6ft 1L LED (Low Temp) | \$129.38 |
| APPLS020 | 4ft 2L LED (Low Temp) | \$149.50 |
| <i>WEATHERIZATION – all electric homes</i> | | |
| WTHRS005 | Seal Doors - Mohair (per linear foot) | \$ 5.00 |
| WTHRS007 | Door Sweeps per Door | \$ 69.00 |
| WTHRS008 | Caulking (per linear foot) | \$ 4.25 |
| WTHRS009 | Expandable Foam (per linear foot) | \$ 20.00 |

| | | |
|-------------------------|--|----------|
| WTHRS006 | Seal Windows - Silicon (per linear foot) | \$ 10.00 |
| WTHRS010 | External Water Heater Insulation (=> 50-Gal Tank) and piping insulation (up to 20ft) | \$326.00 |
| SENSORS/TIMERS | | |
| LGT445 | Wall sensor | \$100.00 |
| LGT445a | Dual Wall Sensor | \$135.00 |
| LGT447 | Lighting timers | \$128.00 |
| LGT448 | Lighting dimmers | \$100.00 |
| | Toggle Switch | \$100.00 |
| APPLS016 | Appliance Timer 120V 10A | \$ 95.00 |
| LGT599 | Photo Cell Sensor | \$ 83.70 |
| LGT600 | Ceiling Mount Sensor | \$186.30 |
| LGT603 | HB3x0-Lx High Bay Line Voltage Passive Infrared Occupancy Sensor | \$186.00 |
| VDM01 | Vending Miser Unit and Installation | \$231.19 |
| VDM02 | Plug Miser Unit and Installation | \$167.57 |
| VDM03 | Cooler Miser Unit and Installation | \$192.00 |
| VDM04 | Snack Miser Unit and Installation | \$180.50 |
| VDM05 | VendingMiser/PlugMiser/CoolerMiser/Snack Miser Installation Only | \$ 86.00 |
| VDM06 | Trickle Star Device | \$ 62.10 |
| Title 24 Sensors | | |
| T24S01 | Light Control Package (Occ. Sensor & Ceiling Mount wireless) | \$313.00 |
| T24S02 | Power Pak Dimming Module | \$248.00 |
| T24S03 | Wireless Vacancy Corner Sensor | \$158.00 |
| T24S04 | Dimmable Wireless Ballast | \$111.00 |
| T24S05 | Daylight Sensor | \$179.00 |

| | | |
|---------------------------------|--|------------|
| T24S06 | Wireless Control Switch | \$109.00 |
| T24S08 | Dual-Circuit Occupancy Sensor Switch | \$173.00 |
| T24S09 | Outdoor photocell sensor | \$ 90.00 |
| T24S10 | Astronomical Time Clock With Holiday Programing | \$358.00 |
| T24S11 | Outdoor Motion Sensor | \$210.00 |
| T24S12 | Indoor Time Clock | \$328.00 |
| CONTROLS | | |
| CTRLS01 | Demand Side Electrical System Control and Monitoring | \$4,200.00 |
| PUMPS AND MOTORS | | |
| EM01 | Motors 1.5 HP NEMA Premium Eff. | \$540.00 |
| EM02 | Motors 2 HP NEMA Premium Eff. | \$663.00 |
| EM03 | Motors 3 HP NEMA Premium Eff. | \$908.00 |
| EM04 | Motors 1.5 HP NEMA Premium Eff. totally enclosed | \$724.00 |
| EM05 | Motors 2 HP NEMA Premium Eff. totally enclosed | \$908.00 |
| EM06 | Motors 3 HP NEMA Premium Eff. totally enclosed | \$1,277.00 |
| EM07 | Variable-Speed Water Pump <= 5 HP | \$1,277.00 |
| AC/APPLIANCE REPLACEMENT | | |
| ACS22 | Room AC Replacement 5,000 - 5,999 BTU per Unit | \$375.00 |
| ACS23 | Room AC Replacement 6,000 - 6,999 BTU per Unit | \$594.00 |
| ACS24 | Room AC Replacement 7,000 - 7,999 BTU per Unit | \$850.00 |
| ACS12 | Room AC Replacement 8,000 - 8,999 BTU per Unit | \$897.00 |
| ACS25 | Room AC Replacement 9,000 - 9,999 BTU per Unit | \$915.00 |
| ACS26 | Room AC Replacement 10,000 - 10,999 BTU per Unit | \$945.00 |

| | | |
|-----------------------------|---|----------------|
| ACS27 | Room AC Replacement 11,000 - 11,999 BTU per Unit | \$1,050.0 0 |
| ACS13 | Room AC Replacement 12,000 - 12,999 BTU per Unit | \$1,073.0 0 |
| ACS17 | Room AC Replacement 13,000 - 13,999 BTU per Unit | \$1,158.0 0 |
| ACS18 | Room AC Replacement 14,000 - 14,999 BTU per Unit | \$1,220.0 0 |
| ACS19 | Room AC Replacement 15,000 - 15,999 BTU per Unit | \$1,230.0 0 |
| ACS20 | Room AC Replacement 16,000 - 16,999 BTU per Unit | \$1,230.0 0 |
| ACS21 | Room AC Replacement 17,000 - 17,999 BTU per Unit | \$1,230.0 0 |
| ACS14 | Room AC Replacement 18,000 - 23,999 BTU per Unit | \$1,230.0 0 |
| ACS15 | Room AC Replacement 24,000 BTU per Unit | \$1,230.0 0 |
| ACS16 | Power Cord | \$ 33.72 |
| ACS30 | Pig Tails | \$ 28.32 |
| Heat Pump Units (HP) | | |
| ACS28 | Room HP Replacement 5,000 - 5,999 BTU per Unit | \$431.25 |
| ACS29 | Room HP Replacement 6,000 - 6,999 BTU per Unit | \$683.10 |
| ACS30 | Room HP Replacement 7,000 - 7,999 BTU per Unit | \$908.27 |
| ACS31 | Room HP Replacement 8,000 - 8,999 BTU per Unit | \$963.70 |
| ACS32 | Room HP Replacement 9,000 - 9,999 BTU per Unit | \$1,012.00 |
| ACS33 | Room HP Replacement 10,000 - 10,999 BTU per Unit | \$ 1,105.00 |
| ACS34 | Room HP Replacement 11,000 - 11,999 BTU per Unit | \$ 1,105.00 |
| ACS35 | Room HP Replacement 12,000 - 12,999 BTU per Unit | \$ 1,120.00 |

| | | |
|---|--|----------------|
| ACS36 | Room HP Replacement 13,000 - 13,999 BTU per Unit | \$ 1,230.00 |
| ACS37 | Room HP Replacement 14,000 - 14,999 BTU per Unit | \$ 1,230.00 |
| ACS38 | Room HP Replacement 15,000 - 15,999 BTU per Unit | \$ 1,250.00 |
| ACS39 | Room HP Replacement 16,000 - 16,999 BTU per Unit | \$ 1,250.00 |
| ACS40 | Room HP Replacement 17,000 - 17,999 BTU per Unit | \$ 1,250.00 |
| ACS41 | Room HP Replacement 18,000 - 23,999 BTU per Unit | \$ 1,270.00 |
| ACS42 | Room HP Replacement 24,000 BTU per Unit | \$1,270.0 0 |
| ACS43 | AC/HP Drain Pan | \$ 60.96 |
| ACS44 | AC/HP Adapter Plug | \$ 13.36 |
| MISCELLANEOUS | | |
| LABORS06 | High Ceiling charge per fixture | \$ 3.50 |
| LABORS07 | Scissor Lift per day | \$280.00 |
| ADDITIONAL SERVICES (CONSULTING) | | |
| LABOR04 | RHA Labor (hourly) | \$ 66.00 |
| LABOR05 | Small Business Energy Audit & Report less than 75kW | \$200.00 |
| LABOR06 | Small Business Advanced Energy Audit & Report | \$500.00 |
| LABOR06a | Billing Inquiry/High Bill Complaint Energy Audit & Report | \$500.00 |
| LABOR07 | Measurements and Verification (Metering hourly rate) | \$110.00 |
| LABOR08 | IT Consulting Services (hourly) | \$ 90.00 |
| LABOR11 | Smart Thermostat Installation Only | \$164.00 |

INDUSTRY PUBLIC UTILITIES COMMISSION

ITEM NO. 6.5



INDUSTRY PUBLIC UTILITIES COMMISSION

MEMORANDUM

TO: Honorable President Moss and Commissioners

FROM: Joshua Nelson, City Manager

STAFF: Mathew Hudson, Engineering Manager
Dev Birla, Senior Energy Adviser, CNC Engineering

DATE: April 11, 2024

SUBJECT: Consideration of an Energy Efficiency Program Reimbursement, to Kelly Spicers for the property located at 288 South Brea Canyon Road, in the amount of \$29,059.89

Background:

On November 15, 2023, Kelly Spicers ("Customer"), tenant of the property located at 288 South Brea Canyon Road, approached IPU Staff to inquire about the Energy Efficiency ("EE") Incentive Program. On December 13, 2023, the Customer provided information about a planned LED Lighting Upgrade project to replace existing lighting fixtures with LEDs and applied for the EE Incentive Program. A pre- inspection site visit occurred on December 20, 2023, in which both IPU's consultant RHA, and Customer's representative walked the whole facility to fully understand the scope of the proposed project.

RHA reviewed the proposed project in detail, verified the calculated energy savings and prepared a pre-inspection report (see attached Exhibit A). Based on that report, a generic pre- approval letter was sent to the Customer that it may be eligible for reimbursement of \$29,059.89 under the EE Incentive Program. The reimbursement is pending the verification of implementation of the proposed project and savings in energy in the post-inspection and approval by the Commission. The Customer completed the replacement of lighting fixtures with energy-efficient LEDs and notified IPU about the completion in February 2024. RHA performed the post-inspection on the project site on February 29, 2024, and submitted a post- inspection report as shown in Exhibit B. The Customer has submitted a copy of the final invoice, provided in Exhibit C.

Discussion:

Specifically, in both the reports (pre- inspection and post-inspection), the annual energy savings were calculated to be 370,183 kWh, reduction in peak demand 62.73 kW with an annual cost saving in energy to be \$54,416.00. The final invoice of this project is \$121,977.66, out of which the material cost is \$58,119.78, excluding 9.5 percent sales tax.

Under the Amended and Restated Energy Efficiency Program effective January 1, 2024, the Customer is entitled to reimbursement for one year of energy saving at 0.059/kW and peak reduction cost of \$150/kW which cannot not exceed 50 percent of the cost of the material of the final invoice, capped at \$50,000.00 for any customer over two years. Each electric meter is considered as a customer. At 288 South Brea Canyon, Kelly Spicers has one electric meter and is entitled to the reimbursement in an amount of \$29,059.89, including \$7,219.00 for the peak reduction incentive that, upon approval, reflects the proposed change to the new Large General Service Lighting Incentive program retroactively to January 1, 2024. Any EE Incentive amount exceeding \$10,000 to any customer must be approved by the Commission.

Fiscal Impact:

The fiscal impact is \$29,059.89. This reimbursement will come out of \$155,000.00 budgeted in adopted fiscal year budget 2023-24, under Account No. 161-300-6415.

Recommendation:

It is hereby recommended that the IPUC approve the reimbursement of \$29,059.89 to Kelly Spicers under the LED Lighting Incentive Program.

Exhibits:

- A. Pre-Inspection Energy Analysis Report
- B. Post-Inspection Energy Analysis Report
- C. Copy of Final Invoice

JN/MH/DB:jf

EXHIBIT A

Pre-Inspection Energy Analysis Report

[Attached]

Pre-Inspection Energy Analysis Report

January 2024

Prepared for:

Kelly Spicers

288 Brea Canyon Road,
City of Industry, CA 91789

Submitted By:



Richard Heath & Associates, Inc.
rhainc.com

On Behalf of:



Industry Public Utilities
15651 Mayor Dave Way
City of Industry, CA 91744

Disclaimer:

The attached energy audit report is prepared by Richard Heath and Associates, Inc. (RHA) on behalf of the City of Industry Public Utilities. This study was conducted with reasonable care and in accordance with professional standards. The results were calculated in accordance to the operating conditions as stated by the customer/contractor or as measures during the Measurement & Verifications (M&V) process at the time of the study, the actual results may change and are subject to operating conditions.

Table of Contents

| | | |
|---|--|----|
| 1 | Program Description..... | 4 |
| 2 | Executive Summary | 5 |
| | 2.1 Energy Efficiency Potential | 5 |
| | 2.2 Facility Description | 5 |
| | 2.3 Environmental Benefits | 5 |
| 3 | Electric Consumption, Calibration Notes and Distribution | 5 |
| | 3.1 Energy Rate Schedule | 6 |
| | 3.2 Electric Billing History | 6 |
| 4 | Energy Efficiency Measures And Recommendations | 7 |
| | 4.1 Lighting Replacement | 7 |
| 5 | List of Preparers | 8 |
| | APPENDIX A: Facility and Equipment Images | 9 |
| | APPENDIX B: Lighting Details | 10 |

1 PROGRAM DESCRIPTION

Richard Heath and Associates, Inc. (RHA) is a consulting firm that specializes in energy conservation. RHA created this pre-inspection energy analysis report on behalf of City of Industry Public Utilities (IPUC).

The intent of the report is to analyze the energy consumption and determine the energy savings opportunity from upgrading the lighting system of the facility. This information will enable both corporate and facility management to better understand the energy use at the facility, which in turn will enhance the ability of personnel to focus on prudent and productive energy conservation actions, whether temporary or permanent in nature.

2 EXECUTIVE SUMMARY

RHA developed this pre-inspection report with the purpose of identifying energy saving opportunities at **Kelly Spicers** from upgrading the lighting system. This section includes a summary of the findings with subsequent sections including the details of the proposed Energy Conservation Measures (ECMs).

2.1 Energy Efficiency Potential

RHA engineers analyzed the lighting ECM to help the facility reduce energy consumption. Table 1 includes estimated annual energy savings, cost savings, and estimated project cost. All the ECMs recommended in Table 1 are suggested to go through the City of Industry Public Utilities Energy Efficiency Program for utility incentives. RHA conducted an assessment at Kelly Spicers to determine the baseline consumption for their interior lighting. The most recent 12-month billing data was used to compare the interior lighting baseline consumption and verify it aligns with the overall estimated building usage profile. RHA compared the proposed energy efficiency measures and calculated an estimated savings and simple payback. A summary table of the reflected savings is shown in table 1. For specific details pertaining to Table 1, please refer to section 4.1(Lighting Replacement) and APPENDIX B (Lighting Details).

Table 1: Energy Conservation Measure Summary

| Energy Conservation Measure | Annual Cost Savings (\$/year) | Electricity Savings (kWh/year) | Demand Reduction (kW) | Estimated Incentives* (\$) | Material Cost (\$) | Estimated Project Cost (\$) | NPV (Based on EUL of measure) | EUL (years) | Simple Payback (years) |
|-----------------------------------|-------------------------------|--------------------------------|-----------------------|----------------------------|--------------------|-----------------------------|-------------------------------|-------------|------------------------|
| LED Lighting Upgrade and Controls | \$54,416 | 370,183 | 62.73 | \$29,059.89 | \$58,119 | \$114,829 | \$603,048 | 11 | 1.57 |
| Total | \$54,416 | 370,183 | 62.73 | \$29,059.89 | \$58,119 | \$114,829 | \$603,048 | 11 | 1.57 |

**Incentive amount is based on the program guidelines' rate of 0.059\$/kWh saved for one year of energy savings, and \$150/kW reduced. A maximum incentive of \$50,000 over a two-year budget cycle or 50% of material cost, whichever is less.*

2.2 Facility Description

Kelly Spicers is an industrial distributor located at 288 Brea Canyon Road, City of Industry, CA 91789. The facility operates Monday through Friday from 8:00 AM to 5:00 PM.

2.3 Environmental Benefits

Environmental benefits from the proposed recommendations include the reduction of greenhouse gas (GHG) emissions. The annual energy savings of 370,183 kWh is equivalent to 289 Tons of avoided Carbon Dioxide emissions for one year. In perspective, this is equivalent to removing 58 passenger vehicles driven for one year (epa.gov).

3 ELECTRIC CONSUMPTION, CALIBRATION NOTES AND DISTRIBUTION

The monthly energy consumption (kWh) and electric demand (kW) at the facility is presented in this section.

3.1 Energy Rate Schedule

The following table summarizes the electric account information for this facility.

Table 2: Utility Rates

| Service Address | Typical Blended Electric Rate* (\$/kWh) |
|----------------------|---|
| 288 Brea Canyon Road | \$0.147/kWh |

**Typical IPU blended rate of \$0.147/kWh was used for energy saving calculations only and does not constitute the actual rate charges for this customer.*

3.2 Electric Billing History

Figure 1 details the monthly meter data for the entire facility within a 12-month period, from December 2022 to November 2023. The average monthly electric consumption for the meter is 74,146.70 kWh resulting in an annual consumption of 889,760 kWh. Please note that the data below is specifically for the entire facilities consumption within a 12-month period. For more information specific to lighting consumption, please see section 4.1 (Lighting Replacement).

Figure 1: Monthly Energy Consumption (kWh)





Figure 2 illustrates the energy demand (kW) of the facility per month. The highest peak demand was recorded in the months of August 2023 to October 2023 at 196.8 kW.

Figure 2: Monthly Electric Peak Demand (kW)



4 ENERGY EFFICIENCY MEASURES AND RECOMMENDATIONS

This section explains potential electric and financial savings in detail. The major equipment analyzed is interior lighting.

4.1 Lighting Replacement

The existing lighting at the facility consists of linear fluorescent and high-pressure sodium (HPS) fixtures. RHA conducted a lighting inspection at Kelly Spicers to verify the existing lighting fixtures and wattage loads (**see APPENDIX B for a breakdown by location**). The contractor provided us with a proposed LED fixture model and specifications which was used to determine the future consumption. With all this information, the original baseline consumption for existing indoor fixtures was calculated to be 555,581 kWh/year and the new proposed indoor lighting fixtures to be 261,417kWh/year, resulting in 294,165kWh saved per year.

Additional, to the lighting replacement, lighting controls are to be installed in the warehouse locations. The RHA team estimates that occupancy lighting control sensors will reduce consumption by 30%, this is based on the Vermont Electric Energy Efficiency Potential Study. Ultimately with this methodology the lighting controls to be installed warrant an additional 76,018kWh saved per year. In total, the combined savings from the LED replacement and lighting controls upgrade for the project is projected to reduce **370,183kWh per year**. As well, the LED Lighting replacement was calculated to result in a demand reduction of **62.73kW**. The incentive calculations are based on the combined rates of 0.059\$/kWh and \$150/kW saved in one year. Applying these incentive rates and program guidelines, the rates are multiplied by the estimated savings in one-year. This results in an incentive amount of \$29,059.89 (**program guideline is based on the rate of 0.059\$/kWh and \$150/kW saved for one year of energy savings and limit incentives to \$50,000 over a two-year budget cycle or 50% of material cost, whichever is less**). Please note that based off these guidelines, the incentive is capped at 50% the material cost, resulting in an incentive amount for \$29,059.89. The full list of proposed lighting measures can be found in APPENDIX B (Lighting Details).

Table 3 summarizes the financial and environmental savings from the project.

Table 3: Lighting Replacement Savings

| Energy Conservation Measure | Annual Cost Savings (\$/year) | Electricity Savings (kWh/year) | Demand Reduction (kW) | Estimated Incentives (\$) | Material Cost (\$) | Estimated Project Cost (\$) | NPV (Based on EUL of measure) | EUL (years) | Simple Payback (years) |
|------------------------------------|-------------------------------|--------------------------------|-----------------------|---------------------------|--------------------|-----------------------------|-------------------------------|-------------|------------------------|
| LED Lighting Upgrade and Controls* | \$54,416 | 370,183 | 62.73 | \$29,059.89 | \$58,119 | \$114,829 | \$603,048 | 11 | 1.57 |
| Total | \$54,416 | 370,183 | 62.73 | \$29,059.89 | \$58,119 | \$114,829 | \$603,048 | 11 | 1.57 |

*The RHA team estimates that occupancy sensors will reduce energy consumption by 30% of the interior lighting consumption. Based on the [Vermont Electric Energy Efficiency Potential Study](#) by SDG Associates, inc. January 2007. Please note that this only applies to locations where occupancy sensors/lighting controls will be installed.


5 LIST OF PREPARERS

The following members of the RHA Team prepared this report.

Table 4: List of Preparers

| Name | Designation | Contact |
|------------------|------------------|--|
| Tristan Williams | Engineer Intern | TWilliams@rhainc.com |
| Jorge Zamorano | Engineer I | JZamorano@rhainc.com |
| Alejandro Alcala | Engineer Manager | AAcala@rhainc.com |

APPENDIX A: FACILITY AND EQUIPMENT IMAGES

| | |
|---|--|
|  |  |
| <p>Kelly Spicers Warehouse</p> | <p>Kelly Spicers Warehouse</p> |
|  |  |
| <p>Kelly Spicers Warehouse</p> | <p>Kelly Spicers Warehouse</p> |
|  |  |
| <p>Kelly Spicers Open Storage</p> | <p>Kelly Spicers Open Storage</p> |
|  |  |
| <p>Kelly Spicers Floor Plan</p> | <p>Kelly Spicers Floor Plan</p> |

APPENDIX B: LIGHTING DETAILS

| LIGHTING INCENTIVE WORKSHEET | | | | | |
|------------------------------|---------------------|----------------|----------------------------|-----------------------|------------|
| Doing Business As | Kelly Spicers | Vendor Company | Foresight Energy Solutions | Pre-Inspection Date: | 12/20/2023 |
| Account Address | 288 Brea canyon Rd. | Contact Name | Era Tadevosian | Post-Inspection Date: | |

| | |
|--------------------------------|-------------------------------|
| ENTER TOTAL MATERIAL COST (\$) | ENTER TOTAL PROJECT COST (\$) |
| \$58,119.78 | \$114,829.00 |

| Existing Lighting System | | | | | | | | | | New Lighting System | | | | | | | |
|--------------------------|-------------|------------|---------|--------------------------|---------------|------------------|------------------------|------|-------|---------------------|---------------------|---------------|------------------|------------------------|------|-------|-------------|
| Space/ Location | Hou rs/ Day | Days/ week | Control | Existing Lighting System | Watts / Fixt. | Fixture Quantity | Estimated Annual Hours | kW | kWh | Control | New Lighting System | Watts / Fixt. | Fixture Quantity | Estimated Annual Hours | kW | kWh | kWh Control |
| Storage | 2 | 5 | No | 4ft 2L T8 | 74 | 2 | 520 | 0.15 | 77 | No | LED 4ft 2L T8 | 21 | 2 | 520 | 0.04 | 22 | 0 |
| Office 1 - first floor | 8 | 5 | No | 4ft 3L T8 | 111 | 12 | 2,080 | 1.33 | 2,771 | No | LED 4ft 3L T8 | 32 | 12 | 2,080 | 0.38 | 786 | 0 |
| Men RR | 4 | 5 | No | 4ft 2L T8 | 74 | 3 | 1,040 | 0.22 | 231 | No | LED 4ft 2L T8 | 21 | 3 | 1,040 | 0.06 | 66 | 0 |
| Custodial | 2 | 5 | No | 4ft 2L T8 | 74 | 1 | 520 | 0.07 | 38 | No | LED 4ft 2L T8 | 21 | 1 | 520 | 0.02 | 11 | 0 |
| Womens RR | 4 | 5 | No | 4ft 2L T8 | 74 | 3 | 1,040 | 0.22 | 231 | No | LED 4ft 2L T8 | 21 | 3 | 1,040 | 0.06 | 66 | 0 |
| Office 2 - first floor | 8 | 5 | No | LED Flat Panel | 40 | 8 | 2,080 | 0.32 | 666 | No | No Recommendation | 40 | 8 | 2,080 | 0.32 | 666 | 0 |
| Office 3 - first floor | 8 | 5 | No | LED Flat Panel | 40 | 6 | 2,080 | 0.24 | 499 | No | No Recommendation | 40 | 6 | 2,080 | 0.24 | 499 | 0 |
| Office 4 - first floor | 8 | 5 | No | 4ft 2L T8 | 74 | 9 | 2,080 | 0.67 | 1,385 | No | LED 4ft 2L T8 | 21 | 9 | 2,080 | 0.19 | 393 | 0 |
| Open Storage | 4 | 5 | No | 4ft 3L T8 | 111 | 49 | 1,040 | 5.44 | 5,657 | No | LED 4ft 3L T8 | 32 | 49 | 1,040 | 1.54 | 1,605 | 0 |
| VP | 8 | 5 | No | 4ft 3L T8 | 111 | 2 | 2,080 | 0.22 | 462 | No | LED 4ft 3L T8 | 32 | 2 | 2,080 | 0.06 | 131 | 0 |
| Ronnie | 8 | 5 | No | 4ft 3L T8 | 111 | 3 | 2,080 | 0.33 | 693 | No | LED 4ft 3L T8 | 32 | 3 | 2,080 | 0.09 | 197 | 0 |
| Conference | 4 | 5 | No | 4ft 3L T8 | 111 | 6 | 1,040 | 0.67 | 693 | No | LED 4ft 3L T8 | 32 | 6 | 1,040 | 0.19 | 197 | 0 |
| Hallway | 8 | 5 | No | 4ft 3L T8 | 111 | 14 | 2,080 | 1.55 | 3,232 | No | LED 4ft 3L T8 | 32 | 14 | 2,080 | 0.44 | 917 | 0 |

| Existing Lighting System | | | | | | | | | | New Lighting System | | | | | | | |
|--------------------------|-------------------|---------------|---------|--------------------------------|---------------------|---------------------|------------------------------|------|-------|---------------------|------------------------|---------------------|---------------------|------------------------------|------|-----|----------------|
| Space/ Location | Hou rs/ Day | Days/ week | Control | Existing Lighting System | Watts / Fixt. | Fixture Quantity | Estimated Annual Hours | kW | kWh | Control | New Lighting System | Watts / Fixt. | Fixture Quantity | Estimated Annual Hours | kW | kWh | kWh Control |
| File | 8 | 5 | No | 4ft 3L T8 | 111 | 3 | 2,080 | 0.33 | 693 | No | LED 4ft 3L T8 | 32 | 3 | 2,080 | 0.09 | 197 | 0 |
| Break | 8 | 5 | No | 4ft 2L T8 | 74 | 12 | 2,080 | 0.89 | 1,847 | No | LED 4ft 2L T8 | 21 | 12 | 2,080 | 0.25 | 524 | 0 |
| Stairway | 6 | 5 | Yes | 4ft 2L T8 | 74 | 2 | 1,092 | 0.15 | 162 | No | LED 4ft 2L T8 | 21 | 2 | 1,560 | 0.04 | 46 | 0 |
| Marketing | 6 | 2 | No | 4ft 3L T8 | 111 | 7 | 624 | 0.78 | 485 | No | LED 4ft 3L T8 | 32 | 7 | 624 | 0.22 | 138 | 0 |
| Hallway 2 | 6 | 2 | Yes | 4ft 2L T8 | 74 | 20 | 437 | 1.48 | 646 | No | LED 4ft 2L T8 | 21 | 20 | 624 | 0.42 | 183 | 0 |
| Office 1 - Upstairs | 6 | 2 | Yes | 4ft 3L T8 | 111 | 2 | 437 | 0.22 | 97 | No | LED 4ft 3L T8 | 32 | 2 | 624 | 0.06 | 28 | 0 |
| Rod | 6 | 2 | Yes | 4ft 3L T8 | 111 | 2 | 437 | 0.22 | 97 | No | LED 4ft 3L T8 | 32 | 2 | 624 | 0.06 | 28 | 0 |
| Office 2 - Upstairs | 6 | 2 | Yes | 4ft 3L T8 | 111 | 2 | 437 | 0.22 | 97 | No | LED 4ft 3L T8 | 32 | 2 | 624 | 0.06 | 28 | 0 |
| Office 3 - Upstairs | 6 | 2 | Yes | 4ft 3L T8 | 111 | 3 | 437 | 0.33 | 145 | No | LED 4ft 3L T8 | 32 | 3 | 624 | 0.09 | 41 | 0 |
| Office 4 - Upstairs | 6 | 2 | Yes | 4ft 3L T8 | 111 | 2 | 437 | 0.22 | 97 | No | LED 4ft 3L T8 | 32 | 2 | 624 | 0.06 | 28 | 0 |
| Break room | 6 | 2 | Yes | 4ft 3L T8 | 111 | 2 | 437 | 0.22 | 97 | No | LED 4ft 3L T8 | 32 | 2 | 624 | 0.06 | 28 | 0 |
| Open area | 6 | 2 | Yes | 4ft 2L T8 | 74 | 45 | 437 | 3.33 | 1,455 | No | LED 4ft 2L T8 | 21 | 45 | 624 | 0.95 | 413 | 0 |
| Stairway 2 | 6 | 2 | Yes | 4ft 2L T8 | 74 | 6 | 437 | 0.44 | 194 | No | LED 4ft 2L T8 | 21 | 6 | 624 | 0.13 | 55 | 0 |
| Storage 2 | 6 | 2 | Yes | 4ft 2L T8 | 74 | 2 | 437 | 0.15 | 65 | No | LED 4ft 2L T8 | 21 | 2 | 624 | 0.04 | 18 | 0 |
| Josh | 6 | 2 | Yes | 4ft 2L T8 | 74 | 8 | 437 | 0.59 | 259 | No | LED 4ft 2L T8 | 21 | 8 | 624 | 0.17 | 73 | 0 |

| Existing Lighting System | | | | | | | | | | New Lighting System | | | | | | | | |
|--------------------------|-------------|------------|---------|--------------------------|---------------|------------------|------------------------|--------------|----------------|---------------------|---------------------|---------------|------------------|------------------------|----------|--------------|----------------|---------------|
| Space/ Location | Hou rs/ Day | Days/ week | Control | Existing Lighting System | Watts / Fixt. | Fixture Quantity | Estimated Annual Hours | kW | kWh | Control | New Lighting System | Watts / Fixt. | Fixture Quantity | Estimated Annual Hours | kW | kWh | kWh Control | |
| Other rooms | 6 | 2 | Yes | 4ft 3L T8 | 111 | 20 | 437 | 2.22 | 970 | No | LED 4ft 3L T8 | 32 | 20 | 624 | 0.63 | 275 | 0 | |
| Locker rooms | 6 | 2 | Yes | 4ft 3L T8 | 111 | 8 | 437 | 0.89 | 388 | No | LED 4ft 3L T8 | 32 | 8 | 624 | 0.25 | 110 | 0 | |
| HR | 6 | 2 | Yes | 4ft 3L T8 | 111 | 10 | 437 | 1.11 | 485 | No | LED 4ft 3L T8 | 32 | 10 | 624 | 0.32 | 138 | 0 | |
| Fire | 6 | 2 | Yes | 4ft 3L T8 | 111 | 4 | 437 | 0.44 | 194 | No | LED 4ft 3L T8 | 32 | 4 | 624 | 0.13 | 55 | 0 | |
| Restroom | 6 | 2 | Yes | 4ft 2L T8 | 74 | 6 | 437 | 0.44 | 194 | No | LED 4ft 2L T8 | 21 | 6 | 624 | 0.13 | 55 | 0 | |
| Storage 3 | 6 | 2 | Yes | 4ft 2L T8 | 74 | 1 | 437 | 0.07 | 32 | No | LED 4ft 2L T8 | 21 | 1 | 624 | 0.02 | 9 | 0 | |
| Warehouse | 24 | 5 | No | 4ft 6L T8 HO | 226 | 376 | 6,240 | 84.98 | 530,250 | Yes | LED 4ft 6L T8 HO | 108 | 376 | 4,368 | 40.61 | 253,394 | 76,018 | |
| GRAND TOTAL | | | | | | 661 | | 111.2 | 555,581 | | | | | 661 | - | 48.44 | 261,417 | 76,018 |

| Energy Savings | | | | |
|----------------|--------------|----------------|---------------|----------------|
| | kW | kWh | Control kWh | Total kWh |
| Existing | 111.18 | 555,581 | 0 | 555,581 |
| Proposed | 48.43 | 261,417 | 76,018 | 337,435 |
| Total | 62.73 | 294,165 | 76,018 | 370,183 |

| LIGHTING & CONTROLS INCENTIVE | | | | | |
|--|------------------------------|----------------|-----------------|---------------------|----------------------|
| | Annual Energy Savings | | | | |
| Category | kW | kWh | Quantity | kW Incentive | kWh Incentive |
| LED Lighting | 62.7 | 294,165 | 661 | \$ 9,409.88 | \$ 17,355.71 |
| Lighting Controls Upgrade | 0.0 | 76,018 | 1 | 0 | \$ 4,485.07 |
| Total | 62.7 | 370,183 | 662 | \$ 9,409.88 | \$ 21,840.78 |
| Savings % | 56.43% | 66.63% | | | |
| Incentive by Savings | | | | | \$ 31,250.66 |
| Final Incentive* | | | | | \$ 29,059.89 |

| Incentive Table Rates | |
|--|--------------------------------|
| | Lighting & Controls |
| Per kW | \$150.00 |
| Per kWh | \$0.059 |
| Max Incentive Amount NOT to Exceed per Customer | \$50,000.00 |
| or | |
| Max Incentive % Amount NOT to Exceed material cost per Customer | 50% |

*Please note that based off the program guidelines, the incentive is capped at 50% the material cost, resulting in an incentive amount for \$29,059.89

EXHIBIT B

Post-Inspection Energy Analysis Report

[Attached]

Post-Inspection Energy Analysis Report

March 2024

Prepared for:

Kelly Spicers

288 Brea Canyon Road,
City of Industry, CA 91789

Submitted By:



Richard Heath & Associates, Inc.
rhainc.com

On Behalf of:



Industry Public Utilities
15651 Mayor Dave Way
City of Industry, CA 91744

Disclaimer:

The attached energy audit report is prepared by Richard Heath and Associates, Inc. (RHA) on behalf of the City of Industry Public Utilities. This study was conducted with reasonable care and in accordance with professional standards. The results were calculated in accordance with the operating conditions as stated by the customer/contractor or as measures during the Measurement & Verifications (M&V) process at the time of the study, the actual results may change and are subject to operating conditions

Table of Contents

| | | |
|---|---|---|
| 1 | Program Description | 4 |
| 2 | Executive Summary..... | 4 |
| | 2.1 Energy Efficiency Potential | 4 |
| | 2.2 Facility Description | 4 |
| | 2.3 Environmental Benefits | 4 |
| 3 | Electric Consumption, Calibration Notes and Distribution..... | 5 |
| | 3.1 Energy Rate Schedule | 5 |
| | 3.2 Electric Billing History | 5 |
| 4 | Energy Efficiency Measures And Recommendations | 6 |
| | 4.1 Lighting Replacement | 6 |
| 5 | List of Preparers | 7 |
| | APPENDIX A: Facility and Equipment Images | 8 |
| | APPENDIX B: Lighting Details | 9 |

1 PROGRAM DESCRIPTION

Richard Heath and Associates, Inc. (RHA) is a consulting firm that specializes in energy conservation. RHA created this post-inspection energy analysis report on behalf of City of Industry Public Utilities Commission (IPUC).

The intent of the report is to verify the project installation and determine the final energy savings amount and incentive granted from upgrading the lighting system of the facility. This information will enable both corporate and facility management to better understand the savings from the project.

2 EXECUTIVE SUMMARY

RHA developed this post-inspection report with the purpose of identifying energy saving opportunities at **Kelly Spicers** from completing their LED Lighting upgrade. This section includes a summary of the findings with subsequent sections including the details of the proposed Energy Efficiency Measures (ECMs).

2.1 Energy Efficiency Potential

RHA engineers analyzed the lighting ECM to help the facility reduce energy consumption. Table 1 includes estimated annual energy savings, cost savings, and estimated project cost. All the ECMs recommended in Table 1 are suggested to go through the City of Industry Public Utilities Energy Efficiency Program for utility incentives.

Table 1: Energy Conservation Measure Summary

| Energy Conservation Measure | Annual Cost Savings (\$/year) | Electricity Savings (kWh/year) | Demand Reduction (kW) | Estimated Incentives* (\$) | Material Cost (\$) | Estimated Project Cost (\$) | NPV (Based on EUL of measure) | EUL (years) | Simple Payback (years) |
|-----------------------------------|-------------------------------|--------------------------------|-----------------------|----------------------------|--------------------|-----------------------------|-------------------------------|-------------|------------------------|
| LED Lighting Upgrade and Controls | \$54,416 | 370,183 | 62.73 | \$29,059.89 | \$58,119 | \$114,829 | \$603,048 | 11 | 1.57 |
| Total | \$54,416 | 370,183 | 62.73 | \$29,059.89 | \$58,119 | \$114,829 | \$603,048 | 11 | 1.57 |

*Incentive amount is based on the program guidelines' rate of 0.059\$/kWh saved for one year of energy savings, and \$150/kW reduced. A maximum incentive of \$50,000 over a two-year budget cycle or 50% of material cost, whichever is less.

2.2 Facility Description

Kelly Spicers is an industrial distributor located at 288 Brea Canyon Road, City of Industry, CA 91789. The facility operates Monday through Friday from 8:00 AM to 5:00 PM.

2.3 Environmental Benefits

Environmental benefits from the proposed recommendations include the reduction of greenhouse gas (GHG) emissions. The annual energy savings of 370,183 kWh is equivalent to 289 Tons of avoided Carbon Dioxide emissions for one year. In perspective, this is equivalent to removing 58 passenger vehicles driven for one year (epa.gov).

3 ELECTRIC CONSUMPTION, CALIBRATION NOTES AND DISTRIBUTION

The monthly energy consumption (kWh) and electric demand (kW) at the facility is presented in this section.

3.1 Energy Rate Schedule

The following table summarizes the electric account information for this facility.

Table 2: Utility Rates

| Service Address | Typical Blended Electric Rate* (\$/kWh) |
|----------------------|---|
| 288 Brea Canyon Road | \$0.147/kWh |

**Typical IPU blended rate of \$0.147/kWh was used for energy saving calculations only and does not constitute the actual rate charges for this customer.*

3.2 Electric Billing History

Figure 1 details the monthly meter data for the entire facility within a 12-month period, from December 2022 to November 2023. The average monthly electric consumption for the meter is 74,146.70 kWh resulting in an annual consumption of 889,760 kWh. Please note that the data below is specifically for the entire facilities consumption within a 12-month period. For more information specific to lighting consumption, please see section 4.1 (Lighting Replacement).

Figure 1: Monthly Energy Consumption (kWh)





Figure 2 illustrates the energy demand (kW) per month. The highest peak demand was recorded in the months of December 2022 to November 2023 at 196.8 kW.

Figure 2: Monthly Electric Peak Demand (kW)



4 ENERGY EFFICIENCY MEASURES AND RECOMMENDATIONS

This section explains electric and financial savings in detail. The major equipment analyzed is interior lighting.

4.1 Lighting Replacement

The existing lighting at the facility consists of linear fluorescent and high-pressure sodium (HPS) fixtures. RHA conducted a lighting inspection at Kelly Spicers to verify the existing lighting fixtures and wattage loads (**see APPENDIX B for a breakdown by location**). The contractor provided us with a proposed LED fixture model and specifications which was used to determine the future consumption. With all this information, the original baseline consumption for existing indoor fixtures was calculated to be 555,581 kWh/year and the new proposed indoor lighting fixtures to be 261,417kWh/year, resulting in 294,165kWh saved per year.

Additional, to the lighting replacement, lighting controls are to be installed in the warehouse locations. The RHA team estimates that occupancy lighting control sensors will reduce consumption by 30%, this is based on the ***Vermont Electric Energy Efficiency Potential Study***. Ultimately with this methodology the lighting controls to be installed warrant an additional 76,018kWh saved per year. In total, the combined savings from the LED replacement and lighting controls upgrade for the project is projected to reduce **370,183kWh per year**. As well, the LED Lighting replacement was calculated to result in a demand reduction of **62.73kW**. The incentive calculations are based on the combined rates of 0.059\$/kWh and \$150/kW saved in one year. Applying these incentive rates and program guidelines, the rates are multiplied by the estimated savings in one-year. This results in an incentive amount of \$29,059.89 (**program guideline is based on the rate of 0.059\$/kWh and \$150/kW saved for one year of energy savings and limit incentives to \$50,000 over a two-year budget cycle or 50% of material cost, whichever is less**). **Please note that based off these guidelines, the incentive is capped at 50% the material cost, resulting in an incentive amount for \$29,059.89**. The full list of proposed lighting measures can be found in APPENDIX B (Lighting Details).

Table 3 summarizes the financial and environmental savings from the project.

Table 3: Lighting Replacement Savings

| Energy Conservation Measure | Annual Cost Savings (\$/year) | Electricity Savings (kWh/year) | Demand Reduction (kW) | Estimated Incentives (\$) | Material Cost (\$) | Estimated Project Cost (\$) | NPV (Based on EUL of measure) | EUL (years) | Simple Payback (years) |
|------------------------------------|-------------------------------|--------------------------------|-----------------------|---------------------------|--------------------|-----------------------------|-------------------------------|-------------|------------------------|
| LED Lighting Upgrade and Controls* | \$54,416 | 370,183 | 62.73 | \$29,059.89 | \$58,119 | \$114,829 | \$603,048 | 11 | 1.57 |
| Total | \$54,468 | 370,183 | 62.7 | \$21,840 | \$58,119 | \$114,829 | \$603,048 | 11 | 1.2 |

*The RHA team estimates that occupancy sensors will reduce energy consumption by 30% of the interior lighting consumption. Based on the [Vermont Electric Energy Efficiency Potential Study](#) by SDG Associates, inc. January 2007. Please note that this only applies to locations where occupancy sensors/lighting controls will be installed.

5 LIST OF PREPARERS

The following members of the RHA Team prepared this report.

Table 4: List of Preparers

| Name | Designation | Contact |
|------------------|---------------------|----------------------|
| Tristan Williams | Engineer Intern | TWilliams@rhainc.com |
| Jorge Zamorano | Engineer I | JZamorano@rhainc.com |
| Alejandro Alcala | Engineering Manager | AAAlcala@rhainc.com |

APPENDIX A: LIGHTING VERIFICATION IMAGES

| | | |
|---|--|---|
|  | |  |
| <p>Kelly Spicers original warehouse lighting</p> | | <p>Kelly Spicers upgraded warehouse lighting</p> |
|  | |  |
| <p>Kelly Spicers original warehouse lighting</p> | | <p>Kelly Spicers upgraded warehouse lighting</p> |
|  | |  |
| <p>Kelly Spicers original open storage lighting</p> | | <p>Kelly Spicers upgraded open Storage lighting</p> |
|  |  | |
| <p>Kelly Spicers upgraded light fixtures</p> | <p>Kelly Spicers LED lamp specs</p> | |

APPENDIX B: LIGHTING DETAILS

| LIGHTING INCENTIVE WORKSHEET | | | | | |
|------------------------------|---------------------|----------------|----------------------------|-----------------------|------------|
| Doing Business As | Kelly Spicers | Vendor Company | Foresight Energy Solutions | Pre-Inspection Date: | 12/20/2023 |
| Account Address | 288 Brea canyon Rd. | Contact Name | Era Tadevosian | Post-Inspection Date: | 3/1/2024 |

| | |
|--------------------------------|-------------------------------|
| ENTER TOTAL MATERIAL COST (\$) | ENTER TOTAL PROJECT COST (\$) |
| \$58,119.78 | \$114,829.00 |

| Existing Lighting System | | | | | | | | | | New Lighting System | | | | | | | |
|--------------------------|-------------|------------|---------|--------------------------|---------------|------------------|------------------------|------|-------|---------------------|---------------------|---------------|------------------|------------------------|------|-------|-------------|
| Space/ Location | Hou rs/ Day | Days/ week | Control | Existing Lighting System | Watts / Fixt. | Fixture Quantity | Estimated Annual Hours | kW | kWh | Control | New Lighting System | Watts / Fixt. | Fixture Quantity | Estimated Annual Hours | kW | kWh | kWh Control |
| Storage | 2 | 5 | No | 4ft 2L T8 | 74 | 2 | 520 | 0.15 | 77 | No | LED 4ft 2L T8 | 21 | 2 | 520 | 0.04 | 22 | 0 |
| Office 1 - first floor | 8 | 5 | No | 4ft 3L T8 | 111 | 12 | 2,080 | 1.33 | 2,771 | No | LED 4ft 3L T8 | 32 | 12 | 2,080 | 0.38 | 786 | 0 |
| Men RR | 4 | 5 | No | 4ft 2L T8 | 74 | 3 | 1,040 | 0.22 | 231 | No | LED 4ft 2L T8 | 21 | 3 | 1,040 | 0.06 | 66 | 0 |
| Custodial | 2 | 5 | No | 4ft 2L T8 | 74 | 1 | 520 | 0.07 | 38 | No | LED 4ft 2L T8 | 21 | 1 | 520 | 0.02 | 11 | 0 |
| Womens RR | 4 | 5 | No | 4ft 2L T8 | 74 | 3 | 1,040 | 0.22 | 231 | No | LED 4ft 2L T8 | 21 | 3 | 1,040 | 0.06 | 66 | 0 |
| Office 2 - first floor | 8 | 5 | No | LED Flat Panel | 40 | 8 | 2,080 | 0.32 | 666 | No | No Recommendation | 40 | 8 | 2,080 | 0.32 | 666 | 0 |
| Office 3 - first floor | 8 | 5 | No | LED Flat Panel | 40 | 6 | 2,080 | 0.24 | 499 | No | No Recommendation | 40 | 6 | 2,080 | 0.24 | 499 | 0 |
| Office 4 - first floor | 8 | 5 | No | 4ft 2L T8 | 74 | 9 | 2,080 | 0.67 | 1,385 | No | LED 4ft 2L T8 | 21 | 9 | 2,080 | 0.19 | 393 | 0 |
| Open Storage | 4 | 5 | No | 4ft 3L T8 | 111 | 49 | 1,040 | 5.44 | 5,657 | No | LED 4ft 3L T8 | 32 | 49 | 1,040 | 1.54 | 1,605 | 0 |
| VP | 8 | 5 | No | 4ft 3L T8 | 111 | 2 | 2,080 | 0.22 | 462 | No | LED 4ft 3L T8 | 32 | 2 | 2,080 | 0.06 | 131 | 0 |
| Ronnie | 8 | 5 | No | 4ft 3L T8 | 111 | 3 | 2,080 | 0.33 | 693 | No | LED 4ft 3L T8 | 32 | 3 | 2,080 | 0.09 | 197 | 0 |
| Conference | 4 | 5 | No | 4ft 3L T8 | 111 | 6 | 1,040 | 0.67 | 693 | No | LED 4ft 3L T8 | 32 | 6 | 1,040 | 0.19 | 197 | 0 |
| Hallway | 8 | 5 | No | 4ft 3L T8 | 111 | 14 | 2,080 | 1.55 | 3,232 | No | LED 4ft 3L T8 | 32 | 14 | 2,080 | 0.44 | 917 | 0 |

| Space/ Location | Hou rs/ Day | Days/ week | Control | Existing Lighting System | Watts / Fixt. | Fixture Quantity | Estimated Annual Hours | kW | kWh | Control | New Lighting System | Watts / Fixt. | Fixture Quantity | Estimated Annual Hours | kW | kWh | kWh Control |
|---------------------|-------------|------------|---------|--------------------------|---------------|------------------|------------------------|------|-------|---------|---------------------|---------------|------------------|------------------------|------|-----|-------------|
| File | 8 | 5 | No | 4ft 3L T8 | 111 | 3 | 2,080 | 0.33 | 693 | No | LED 4ft 3L T8 | 32 | 3 | 2,080 | 0.09 | 197 | 0 |
| Break | 8 | 5 | No | 4ft 2L T8 | 74 | 12 | 2,080 | 0.89 | 1,847 | No | LED 4ft 2L T8 | 21 | 12 | 2,080 | 0.25 | 524 | 0 |
| Stairway | 6 | 5 | Yes | 4ft 2L T8 | 74 | 2 | 1,092 | 0.15 | 162 | Yes | LED 4ft 2L T8 | 21 | 2 | 1,092 | 0.04 | 46 | 0 |
| Marketing | 6 | 2 | No | 4ft 3L T8 | 111 | 7 | 624 | 0.78 | 485 | No | LED 4ft 3L T8 | 32 | 7 | 624 | 0.22 | 138 | 0 |
| Hallway 2 | 6 | 2 | Yes | 4ft 2L T8 | 74 | 20 | 437 | 1.48 | 646 | Yes | LED 4ft 2L T8 | 21 | 20 | 437 | 0.42 | 183 | 0 |
| Office 1 - Upstairs | 6 | 2 | Yes | 4ft 3L T8 | 111 | 2 | 437 | 0.22 | 97 | Yes | LED 4ft 3L T8 | 32 | 2 | 437 | 0.06 | 28 | 0 |
| Rod | 6 | 2 | Yes | 4ft 3L T8 | 111 | 2 | 437 | 0.22 | 97 | Yes | LED 4ft 3L T8 | 32 | 2 | 437 | 0.06 | 28 | 0 |
| Office 2 - Upstairs | 6 | 2 | Yes | 4ft 3L T8 | 111 | 2 | 437 | 0.22 | 97 | Yes | LED 4ft 3L T8 | 32 | 2 | 437 | 0.06 | 28 | 0 |
| Office 3 - Upstairs | 6 | 2 | Yes | 4ft 3L T8 | 111 | 3 | 437 | 0.33 | 145 | Yes | LED 4ft 3L T8 | 32 | 3 | 437 | 0.09 | 41 | 0 |
| Office 4 - Upstairs | 6 | 2 | Yes | 4ft 3L T8 | 111 | 2 | 437 | 0.22 | 97 | Yes | LED 4ft 3L T8 | 32 | 2 | 437 | 0.06 | 28 | 0 |
| Break room | 6 | 2 | Yes | 4ft 3L T8 | 111 | 2 | 437 | 0.22 | 97 | Yes | LED 4ft 3L T8 | 32 | 2 | 437 | 0.06 | 28 | 0 |
| Open area | 6 | 2 | Yes | 4ft 2L T8 | 74 | 45 | 437 | 3.33 | 1,455 | Yes | LED 4ft 2L T8 | 21 | 45 | 437 | 0.95 | 413 | 0 |
| Stairway 2 | 6 | 2 | Yes | 4ft 2L T8 | 74 | 6 | 437 | 0.44 | 194 | Yes | LED 4ft 2L T8 | 21 | 6 | 437 | 0.13 | 55 | 0 |
| Storage 2 | 6 | 2 | Yes | 4ft 2L T8 | 74 | 2 | 437 | 0.15 | 65 | Yes | LED 4ft 2L T8 | 21 | 2 | 437 | 0.04 | 18 | 0 |
| Josh | 6 | 2 | Yes | 4ft 2L T8 | 74 | 8 | 437 | 0.59 | 259 | Yes | LED 4ft 2L T8 | 21 | 8 | 437 | 0.17 | 73 | 0 |
| Other rooms | 6 | 2 | Yes | 4ft 3L T8 | 111 | 20 | 437 | 2.22 | 970 | Yes | LED 4ft 3L T8 | 32 | 20 | 437 | 0.63 | 275 | 0 |

| Space/ Location | Hou rs/ Day | Days/ week | Control | Existing Lighting System | Watts / Fixt. | Fixture Quantity | Estimated Annual Hours | kW | kWh | Control | New Lighting System | Watts / Fixt. | Fixture Quantity | Estimated Annual Hours | kW | kWh | kWh Control | |
|--------------------|-------------|------------|---------|--------------------------|---------------|------------------|------------------------|--------------|----------------|---------|---------------------|---------------|------------------|------------------------|-------|-------------|----------------|--|
| Locker rooms | 6 | 2 | Yes | 4ft 3L T8 | 111 | 8 | 437 | 0.89 | 388 | Yes | LED 4ft 3L T8 | 32 | 8 | 437 | 0.25 | 110 | 0 | |
| HR | 6 | 2 | Yes | 4ft 3L T8 | 111 | 10 | 437 | 1.11 | 485 | Yes | LED 4ft 3L T8 | 32 | 10 | 437 | 0.32 | 138 | 0 | |
| Fire | 6 | 2 | Yes | 4ft 3L T8 | 111 | 4 | 437 | 0.44 | 194 | Yes | LED 4ft 3L T8 | 32 | 4 | 437 | 0.13 | 55 | 0 | |
| Restroom | 6 | 2 | Yes | 4ft 2L T8 | 74 | 6 | 437 | 0.44 | 194 | Yes | LED 4ft 2L T8 | 21 | 6 | 437 | 0.13 | 55 | 0 | |
| Storage 3 | 6 | 2 | Yes | 4ft 2L T8 | 74 | 1 | 437 | 0.07 | 32 | Yes | LED 4ft 2L T8 | 21 | 1 | 437 | 0.02 | 9 | 0 | |
| Warehouse | 24 | 5 | No | 4ft 6L T8 HO | 226 | 376 | 6,240 | 84.98 | 530,250 | Yes | LED 4ft 6L T8 HO | 108 | 376 | 4,368 | 40.61 | 253,394 | 76,018 | |
| GRAND TOTAL | | | | | | 661 | | 111.2 | 555,581 | | | | | 661 | | 48.4 | 261,417 | |

| Energy Savings | | | | |
|-----------------|---------------|----------------|---------------|----------------|
| | kW | kWh | Control kWh | Total kWh |
| Existing | 111.18 | 555,581 | 0 | 555,581 |
| Proposed | 48.43 | 261,417 | 76,018 | 337,435 |
| Total | 62.73 | 294,165 | 76,018 | 370,183 |

| | Energy Savings | | | |
|------------------------|----------------|-------|-------------|-----------|
| Space/ Location | kW | kWh | Control kWh | Total kWh |
| Storage | 0.11 | 55 | 0 | 55 |
| Office 1 - first floor | 0.95 | 1,984 | 0 | 1,984 |
| Men RR | 0.16 | 165 | 0 | 165 |
| Custodial | 0.05 | 28 | 0 | 28 |
| Womens RR | 0.16 | 165 | 0 | 165 |
| Office 2 - first floor | 0.00 | 0 | 0 | 0 |
| Office 3 - first floor | 0.00 | 0 | 0 | 0 |
| Office 4 - first floor | 0.48 | 992 | 0 | 992 |
| Open Storage | 3.90 | 4,051 | 0 | 4,051 |
| VP | 0.16 | 331 | 0 | 331 |
| Ronnie | 0.24 | 496 | 0 | 496 |
| Conference | 0.48 | 496 | 0 | 496 |
| Hallway | 1.11 | 2,315 | 0 | 2,315 |
| File | 0.24 | 496 | 0 | 496 |
| Break | 0.64 | 1,323 | 0 | 1,323 |
| Stairway | 0.11 | 116 | 0 | 116 |
| Marketing | 0.56 | 347 | 0 | 347 |
| Hallway 2 | 1.06 | 463 | 0 | 463 |
| Office 1 - Upstairs | 0.16 | 69 | 0 | 69 |
| Rod | 0.16 | 69 | 0 | 69 |
| Office 2 - Upstairs | 0.16 | 69 | 0 | 69 |
| Office 3 - Upstairs | 0.24 | 104 | 0 | 104 |
| Office 4 - Upstairs | 0.16 | 69 | 0 | 69 |
| Break room | 0.16 | 69 | 0 | 69 |

| Space/ Location | kW | kWh | Control kWh | Total kWh |
|--------------------|--------------|----------------|---------------|----------------|
| Open area | 2.39 | 1,042 | 0 | 1,042 |
| Stairway 2 | 0.32 | 139 | 0 | 139 |
| Storage 2 | 0.11 | 46 | 0 | 46 |
| Josh | 0.42 | 185 | 0 | 185 |
| Other rooms | 1.59 | 695 | 0 | 695 |
| Locker rooms | 0.64 | 278 | 0 | 278 |
| HR | 0.80 | 347 | 0 | 347 |
| Fire | 0.32 | 139 | 0 | 139 |
| Restroom | 0.32 | 139 | 0 | 139 |
| Storage 3 | 0.05 | 23 | 0 | 23 |
| Warehouse | 44.37 | 276,856 | 76,018 | 352,874 |
| GRAND TOTAL | 62.73 | 294,165 | 76,018 | 370,183 |

| |
|---------------------------------|
| TOTAL MATERIAL COST (\$) |
| \$58,119.78 |

LIGHTING & CONTROLS INCENTIVE

| Category | Annual Energy Savings | | Quantity | kW Incentive | kWh Incentive |
|-----------------------------|-----------------------|----------------|------------|--------------------|---------------------|
| | kW | kWh | | | |
| LED Lighting | 62.7 | 294,165 | 661 | \$ 9,409.88 | \$ 17,355.71 |
| Lighting Controls Upgrade | 0.0 | 76,018 | 1 | 0 | \$ 4,485.07 |
| Total | 62.7 | 370,183 | 662 | \$ 9,409.88 | \$ 21,840.78 |
| Savings % | 56.43% | 66.63% | | | |
| Incentive by Savings | | | | | \$ 31,250.66 |
| Final Incentive* | | | | | \$ 29,059.89 |

*Please note that based off the program guidelines, the incentive is capped at 50% the material cost, resulting in an incentive amount for \$29,059.89

| Incentive Table Rates | |
|--|--------------------|
| Lighting & Controls | |
| Per kW | \$150.00 |
| Per kWh | \$0.059 |
| Max Incentive Amount NOT to Exceed per Customer | \$50,000.00 |
| or | |
| Max Incentive % Amount NOT to Exceed material cost per Customer | 50% |

EXHIBIT C

Copy of Final Invoice

[Attached]



Foresight

ENERGY SOLUTIONS

INVOICE
KW-221109-7

9739 Via Roma
Burbank, Ca 91504
p 310-429-7981
f 213-769-6121


Inv No: KW-221109-7
Date: 3/4/24
Terms: Paid In Full

Customer Name : Kelly Spicers
Contact : Josh Hellon
Install Address: 288 Brea Canyon Road
Walnut, CA 91789

Install Completion
Date: 2/23/24

| Qty | Prod Code | Description | Unit Price | Amount |
|------|---------------|---|------------|-------------|
| 2316 | FA-18-T8BP-5 | LED T8 Tube Bypass 18 Watt 4 Foot 5000K 3,222 Lumen 179/LPW 100-277V DLC Standard 5.1 | \$13.35 | \$30,918.60 |
| 514 | PE-114FT8T-4 | LED T8 Type B Ballast Bypass Tube 10.5 Watt 4 Foot 4000K 1,700 Lumen 162LM/W DLC Standard 5.1 | \$11.37 | \$5,844.18 |
| 386 | ME-BLPIROS | Bi-Level PIR Sensor for all High Bays | \$37.00 | \$14,282.00 |
| 29 | ME-16WEMBBUHB | Emergency Battery Backup 16 Watt 90 Minute | \$135.00 | \$3,915.00 |
| 18 | ME-8WEMBBUTR | Emergency Battery Backup Kit 8 Watt 90 Minute | \$125.00 | \$2,250.00 |
| 26 | EXITCOM | LED Emergency Exit Combo Green Face Plate 90 Minute Battery Title 24 | \$35.00 | \$910.00 |

| | |
|--------------------------------|---------------------|
| Subtotal | \$58,119.78 |
| Labor Equipment | \$55,286.50 |
| Sales Tax | \$5,521.38 |
| Shipping Handling Disposal | \$3,050.00 |
| Total Cost | \$121,977.66 |
| Payment Applied | \$121,977.66 |
| Total Net Balance | \$0.00 |

| | |
|--|--------|
| Prepared By: | Notes: |
| Print Name & Title | |
| Date : | |
| Customer Signature :  | |
| Print Name & Title : <u>Melissa McCreight</u> Facilities Admin. | |
| Print Name & Title : <u>Josh Hellon</u> VP of Operations | |
| Date : 3/22/24 | |